



3.0 to 6.0kW Dual String Single Phase

Suitable for solar installations from
2.4kWp up to 9.0kWp (DC)

- **Discreet and Lightweight** - Compact and stylish with whisper quiet operation.
- **Enhanced Generation** - low start-up voltage generates power in low light conditions.
- **Smart Control.** Generation monitoring and optional export limitation.
- **Safe and Reliable.** Factory fitted DC isolator switch for improved safety.
- **10 Year Warranty.**
- **UK Technical and Design Support.**

Specification

| | | CSI3000D | CSI3600D | CSI5000D | CSI6000D |
|-------------------------------------|----|---|-------------|-------------|-------------|
| OUTPUT | | | | | |
| Nominal Output Power | W | 3,000 | 3,600 | 5,000 | 6,000 |
| Nominal Output Apparent Power | VA | 3,000 | 3,600 | 5,000 | 6,000 |
| Max. AC Active Power | W | 3,300 | 3,600 | 5,500 | 6,600 |
| Max. AC Apparent Power | VA | 3,300 | 3,600 | 5,500 | 6,600 |
| Nominal Output Voltage | V | 220/230/240 | 220/230/240 | 220/230/240 | 220/230/240 |
| Nominal AC Grid Frequency | Hz | 50/60 | 50/60 | 50/60 | 50/60 |
| Max. Output Current | A | 14.4 | 16.0 | 24.0 | 28.8 |
| Power Factor | | ~1 (adjustable from 0.8 leading to 0.8 lagging) | | | |
| Max. Total Harmonic Distortion | | <3% | <3% | <3% | <3% |
| INPUT | | | | | |
| Max. Input Power | W | 4,500 | 5,400 | 7,500 | 9,000 |
| Max. Input Voltage | V | 600 | 600 | 600 | 600 |
| MPPT Operating Voltage Range | V | 40~560 | 40~560 | 40~560 | 40~560 |
| Start-up Voltage | V | 50 | 50 | 50 | 50 |
| Nominal Input Voltage | V | 360 | 360 | 360 | 360 |
| Max. Input Current per MPPT | A | 16 | 16 | 16 | 16 |
| Max. Short Circuit Current per MPPT | A | 23 | 23 | 23 | 23 |
| Number of MPPT Trackers | | 2 | 2 | 2 | 2 |
| Number of Strings per MPPT | | 1 | 1 | 1 | 1 |
| EFFICIENCY | | | | | |
| Max. Efficiency | | 97.9% | 97.9% | 97.9% | 97.9% |
| European Efficiency | | 97.0% | 97.0% | 97.3% | 97.4% |

| | | |
|--------------------------------|----|---|
| GENERAL | | |
| Operating Temperature Range | °C | -25 to +60 |
| Relative Humidity | | 0 to 100% |
| Max. Operating Altitude | m | 4,000 |
| Cooling Method | | Natural Convection |
| User Interface | | LED, LCD, WLAN and App |
| Communication | | WiFi or LAN |
| Weight | kg | 12.8, 13.4 (CSI6000) |
| Dimensions (WxHxD) | mm | 350 x 410 x 143 |
| Noise Emission | dB | <25 |
| Topology | | Non-isolated |
| Standby Power Consumption | W | <1 |
| Ingress Protection (IP) Rating | | IP66 |
| DC Connector | | MC4 (4-6 mm ²) |
| AC Connector | | plug and play connector (max 6mm ²) |

| | |
|------------------------------------|-----------------------------|
| PROTECTION | |
| PV Insulation Resistance Detection | Integrated |
| Residual Current Monitoring | Integrated |
| Anti-Islanding Protection | Integrated |
| AC Overcurrent Protection | Integrated |
| AC Short Circuit Protection | Integrated |
| AC Overvoltage Protection | Integrated |
| DC Switch | Integrated |
| DC Surge Protection | Type III (Type II Optional) |
| AC Surge Protection | Type III (Type II Optional) |
| AFCI | Option |
| Emergency Power Off | Option |
| Remote Shutdown | Option |

© Viridian Solar Ltd. 2024. Not to be reproduced either wholly or in part without the express written permission of Viridian Solar Ltd.

Viridian Solar has a policy of continuous improvement, and reserves the right to alter the specifications without notice. Viridian Solar has made every effort to ensure the accuracy of information, but does not accept liability for any errors or omissions.



Clearline Inverter - Limited Guarantee

Viridian Solar Ltd., (hereinafter "Viridian") shall provide to any purchaser ("Purchaser") of its Clearline Inverter and associated Accessories ("Products"), limited guarantees as to the quality and/or performance of its Products in accordance with the following terms and conditions.

1.0 General Conditions

The guarantees will start from the date of installation of the relevant Product and is transferrable to subsequent owners of the location to which the Product is installed. Where the installation date cannot be confirmed, the start date will be taken as one month after the shipment of the product from Viridian. The execution of the guarantees will not lead to any prolongation of the original guarantee period. The guarantees apply to products delivered after 1st January 2023. The Purchaser's statutory rights under applicable national legislation are not affected by the guarantees.

The guarantees are conditional upon the Products being properly handled and installed by competent persons who have correctly followed the installation instructions applicable at that time and have used best-practice methods for their respective trades. It is also contingent on the Products being used in the manner that Viridian intended. The guarantees are also dependant on the proper use and maintenance of the Products according to Viridian's instructions. It is the responsibility of the Purchaser to demonstrate, to the reasonable satisfaction of Viridian, that the exclusions in this section 1.0 and section 3.0 of this document do not apply in respect of any claim under the guarantees.

The guarantees may not be claimed against unless and until the relevant Product has been paid for in full. Any claim under the guarantees shall be promptly notified in writing by the Purchaser as set out in section 4.0 below.

Viridian does not accept liability (whether in tort [including for negligence or breach of statutory duty], contract, misrepresentation or otherwise) for any loss of profits; loss of business; depletion of goodwill or similar losses; loss of anticipated savings; loss of goods; loss of use; or any special, indirect or consequential losses arising from the failure of the Products howsoever caused.

This exclusion of liability does not affect, or attempt to affect, any of the Purchaser's rights under applicable national legislation.

The guarantees do not cover costs associated with installation, removal, or reinstallation of the Products.

In no event will Viridian's aggregate liability under the guarantees exceed the original value of the Products which are the subject of a claim or dispute.

Any exchanged or replaced components or Products shall pass into the ownership of Viridian.

The Purchaser accepts that the Products were not designed and produced to its individual requirements and that the Purchaser was responsible for their selection.

2.0 Product Guarantee

For the purposes of this Product Guarantee, a "Defect" means behaviour of the relevant Product which does not meet the relevant specification set out in the technical data sheet (available at www.viridiansolar.com) and which is caused by failings in the materials or workmanship used or deployed in the production of the relevant Product. For the avoidance of doubt, a Defect does not occur when the Product does not meet a particular need but does meet a reasonable interpretation of the behaviour defined in the technical datasheet.



Viridian guarantees in respect of each Product that, for the periods set out in respect of each Product type below, the relevant Product will not be subject to a Defect.

| Product | Product Code Starting | Years |
|----------------------|-----------------------|-------|
| Clearline Inverter | CSI | 10 |
| Inverter WiFi Module | CSI-WIFI | 2 |

The Purchaser shall promptly notify Viridian of any breach of the above Product Guarantee in accordance with section 4.0.

In the event of a claim being approved, the Purchaser's sole remedy for breach of this Product Guarantee and Viridian's sole obligation shall be that Viridian will, at its sole option, reimburse the Purchaser for the original purchase, repair the Product, or supply a replacement new or refurbished Product. If the type of Product which is subject to the claim is no longer available, a Product of equivalent performance (as judged by Viridian), may be supplied.

The Purchaser shall provide all information as may be deemed necessary by Viridian to assist Viridian in remedying any Defect.

The period of Product Guarantees for any replacement Products supplied pursuant to this Product Guarantee will be equal to the remainder of the guarantee period of the originally supplied Product.

3.0 Exclusions

No claim may be brought after expiry of the applicable guarantee periods.

This Product Guarantee is subject to the following conditions:

- The Product being properly handled and installed by competent persons who have correctly followed the installation instructions applicable at that time and have used best-practice methods for their respective trades.
- The Product is used only on the electricity supply printed on the rating plate.
- The Product is used in the United Kingdom or Republic of Ireland.
- The Product has been used in accordance with the User Guide.
- The serial number of the Product, components or accessories have not been altered, cancelled, or removed.
- The Product has not been altered, serviced, maintained, dismantled or otherwise interfered with by any person not authorised by Viridian. For the avoidance of doubt any attempt to open the unit by anyone other than us or our appointed agent will invalidate the warranty.
- Any repair work must be undertaken by us or our appointed agent having first been agreed with Viridian Technical Support.
- That any return of the Product is done as specified in the Return Materials Authorisation ("RMA") instructions provided by Viridian.

The Guarantee does not cover defects which in Viridian's judgement have been caused by:

- Fair wear and tear (e.g., colour fading, scratches on top cover/machine body).
- Installation that is not in conformance with product specifications, installation instructions, operation manuals, labelling or prevailing standards and regulations
- Any damage due to miswiring, and/or software/hardware misconfiguration
- Failure to demonstrate that recommended maintenance procedures have been followed.
- Defective transportation, storage, or handling



- Usage which does not comply with the safety regulations (VDE, IEC, etc.).
- Operation outside the specified operating temperature and or humidity range
- Use of incompatible spare parts or accessories not supplied or approved by Viridian.
- Unauthorised modification of the Product, including the addition of marks and stickers
- Breakage due to external influences – power surge, flying objects, external loads, vandalism or theft.
- Damage due to shock/vibration.
- Damage due to improper IP protection (dust/fluid ingress)
- Damage caused by external factors – such as dirt, soiling, smoke, chemicals, pollution.
- Damage by natural disasters (such as fires, earthquakes, cyclones, hurricanes, volcano eruptions, lightning, indirect lightning strikes, heavy snow falls, avalanches, frost damage) or other unforeseeable circumstances.
- Relocation from the original place of installation
- Faults caused by interaction with equipment not supplied or approved in writing by Viridian
- Third party software or from virus(es).

The warranty does not cover:

- Product failure not reported to Viridian within one month of appearance.
- Damage resulting from transportation, improper use, wear and tear, neglect or interference or as a result of improper installation.
- Replacement of any consumable item or accessory not supplied by us.
- Any rust that appears on the device's enclosure caused by harsh environmental conditions. Faults or damage caused by exposure to coastal environments/saltwater or other aggressive atmospheres or environmental conditions without Viridian's written confirmation/approval prior to the installation.

Viridian is not responsible for:

- Software loss or data loss that may occur during the repair or replacement of the product.
- Damage to or loss of any program, data, or removable storage media, or for costs of recovering any program or data.
- Confidential, proprietary, or personal information contained in the product which you return to us for any reason.
- Costs associated with de-installation or re-installation of any product.



4.0 Claims Procedure

Claims should be addressed to

warranty@viridiansolar.co.uk

or
Viridian Solar
Atlas Building
68 Stirling Way
Papworth
Cambridge, UK
CB23 3GY

The email must contain the following information regarding the device and the nature of the malfunction:

1. The serial number of the Product.
2. Proof of purchase.
3. Photographs of the Product in current state.
3. Installation information, including brand, model, and number of PV panels; if the defective product is an energy storage system, the brand and model of batteries are also needed.
4. Date of installation, date of malfunction.
5. Detailed description of the malfunction including any error messages on the LCD screen and any actions taken before the claim.

Without this information, your claim cannot be processed.

Viridian will endeavour to respond to the claim within 5 working days and resolve the claim within 28 days.

If we determine that the malfunction is potentially due to causes under warranty, then we will issue a Returns Merchandise Authorisation (RMA) to ship back the unit.

The returns process is as outlined below:

- Once received, Viridian will analyse the device that was returned under the RMA.
- If Viridian determines that the malfunction is due to the causes under warranty, the Product is repaired or replaced and shipped back to the customer (at our expense).
- If Viridian determines that the malfunction is not due to the causes under warranty, the warranty claim is rejected, and the Product is shipped back to the customer (at customer's expense).

When preparing your Product for shipment to Viridian, we recommend the following:

- The Product is returned in its original packaging. The original packaging will provide better protection for the Product during transit. The warranty may be voided if the Product is damaged due to improper packaging.
- Please do not send in anything but the Product itself unless specially requested by us. Any other items and accessories included in the package received by us will be treated as packaging material and may not be returned.
- Please note: if your Product is received packed in anything other than its original packaging, we may invoice you for appropriate anti-shock packaging when your Product is returned.






Form C: Type Test Verification Report

All Micro-generators connected to the **DNO Distribution Network** shall be **Fully Type Tested**. This form is the **Manufacturer's** declaration of compliance with the requirements of EREC G98.

This form should be used when making a Type Test submission to the Energy Networks Association (ENA) Type Test Register.

If the **Micro-generator** is **Fully Type Tested** and already registered with the ENA Type Test Register, the **Installation Document** should include the **Manufacturer's** Reference Number (the system reference), and this form does not need to be submitted.

| | | | |
|--|--------------------------|--|-------------------------|
| Manufacturer's reference number | | Clearline Inverter CSI3000D | |
| Micro-generator technology | | Grid-Connected PV Inverter | |
| Manufacturer name | | Viridian Solar Ltd | |
| Address | | 68 Stirling Way, Papworth Everard, Cambridge, CB23 3GY United Kingdom | |
| Tel | +44 (0)1480 839 865 | Fax | / |
| E-mail | info@viridiansolar.co.uk | Web site | www.viridiansolar.co.uk |
| Registered Capacity , use separate sheet if more than one connection option. | Connection Option | | |
| | 3.0 | kW single phase, single, split or three phase system | |
| | / | kW three phase | |
| | / | kW two phases in three phase system | |
| | / | kW two phases split phase system | |
| Energy storage capacity for Electricity Storage devices | | Not energy storage inverter | |
| <p>Manufacturer Type Test declaration. - I certify that all products supplied by the company with the above Fully Type Tested reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of EREC G98.</p> | | | |
| <p>Note that testing can be done by the Manufacturer of an individual component or by an external test house.</p> <p>Where parts of the testing are carried out by persons or organisations other than the Manufacturer then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.</p> | | | |
| <p>1. Operating Range: This test should be carried out as specified in A.1.2.10.</p> <p>Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.</p> | | | |

| | |
|---|---|
| <p>Test 1</p> <p>Voltage = 85% of nominal (195.5 V)</p> <p>Frequency = 47.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 20 seconds</p> | <p>Result:Pass</p>  |
| <p>Test 2</p> <p>Voltage = 85% of nominal (195.5 V)</p> <p>Frequency = 47.5 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p> | <p>Result:Pass</p>  |
| <p>Test 3</p> <p>Voltage = 110% of nominal (253 V).</p> <p>Frequency = 51.5 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p> | <p>Result:Pass</p>  |
| <p>Test 4</p> <p>Voltage = 110% of nominal (253 V).</p> <p>Frequency = 52.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 15 minutes</p> | <p>Result:Pass</p>  |
| <p>Test 5</p> <p>Voltage = 100% of nominal (230 V).</p> <p>Frequency = 50.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p> | <p>Result:Pass</p>  |

| <p>Test 6 RoCoF withstand</p> <p>Confirm that the Micro-Generating Plant is capable of staying connected to the Distribution Network and operate at rates of change of frequency up to 1 Hzs⁻¹ as measured over a period of 500 ms.</p> | <p>Result: Pass</p> <p>图表标题</p> <p>U-rms-E2[V] f(U-E2)[Hz]</p> <table><tr><th>Time (ms)</th><th>U-rms-E2[V]</th><th>f(U-E2)[Hz]</th></tr><tr><td>1</td><td>230.0</td><td>50.0</td></tr><tr><td>25</td><td>230.0</td><td>50.0</td></tr><tr><td>49</td><td>230.0</td><td>50.0</td></tr><tr><td>73</td><td>230.0</td><td>50.0</td></tr><tr><td>97</td><td>230.0</td><td>50.0</td></tr><tr><td>121</td><td>230.0</td><td>50.0</td></tr><tr><td>145</td><td>230.0</td><td>50.0</td></tr><tr><td>169</td><td>230.0</td><td>50.0</td></tr><tr><td>193</td><td>230.0</td><td>50.0</td></tr><tr><td>217</td><td>230.0</td><td>50.0</td></tr><tr><td>241</td><td>230.0</td><td>50.0</td></tr><tr><td>265</td><td>230.0</td><td>50.0</td></tr><tr><td>289</td><td>230.0</td><td>50.0</td></tr><tr><td>313</td><td>230.0</td><td>50.0</td></tr><tr><td>337</td><td>230.0</td><td>50.0</td></tr><tr><td>361</td><td>230.0</td><td>50.0</td></tr><tr><td>385</td><td>230.0</td><td>50.0</td></tr><tr><td>409</td><td>230.0</td><td>50.0</td></tr><tr><td>433</td><td>230.0</td><td>50.0</td></tr><tr><td>457</td><td>230.0</td><td>50.0</td></tr><tr><td>481</td><td>230.0</td><td>50.0</td></tr><tr><td>505</td><td>230.0</td><td>50.0</td></tr><tr><td>529</td><td>230.0</td><td>50.0</td></tr><tr><td>553</td><td>230.0</td><td>50.0</td></tr><tr><td>577</td><td>230.0</td><td>50.0</td></tr><tr><td>601</td><td>230.0</td><td>50.6</td></tr></table> | Time (ms) | U-rms-E2[V] | f(U-E2)[Hz] | 1 | 230.0 | 50.0 | 25 | 230.0 | 50.0 | 49 | 230.0 | 50.0 | 73 | 230.0 | 50.0 | 97 | 230.0 | 50.0 | 121 | 230.0 | 50.0 | 145 | 230.0 | 50.0 | 169 | 230.0 | 50.0 | 193 | 230.0 | 50.0 | 217 | 230.0 | 50.0 | 241 | 230.0 | 50.0 | 265 | 230.0 | 50.0 | 289 | 230.0 | 50.0 | 313 | 230.0 | 50.0 | 337 | 230.0 | 50.0 | 361 | 230.0 | 50.0 | 385 | 230.0 | 50.0 | 409 | 230.0 | 50.0 | 433 | 230.0 | 50.0 | 457 | 230.0 | 50.0 | 481 | 230.0 | 50.0 | 505 | 230.0 | 50.0 | 529 | 230.0 | 50.0 | 553 | 230.0 | 50.0 | 577 | 230.0 | 50.0 | 601 | 230.0 | 50.6 |
|--|---|-------------|-------------|-------------|---|-------|------|----|-------|------|----|-------|------|----|-------|------|----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|-----|-------|------|
| Time (ms) | U-rms-E2[V] | f(U-E2)[Hz] | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 25 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 49 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 73 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 121 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 145 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 169 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 193 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 217 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 241 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 265 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 289 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 313 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 337 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 361 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 385 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 409 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 433 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 457 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 481 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 505 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 529 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 553 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 577 | 230.0 | 50.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 601 | 230.0 | 50.6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

2. Power Quality – Harmonics: These tests should be carried out as specified in BS EN 61000-3-2. The chosen test should be undertaken with a fixed source of energy at two power levels a) between 45 and 55% and b) at 100% of **Registered Capacity**. The test requirements are specified in Annex A1 A.1.3.1 (**Inverter** connected) or Annex A2 A.2.3.1 (Synchronous).

| Micro-generator tested to BS EN 61000-3-2 | | | | | | |
|--|--|-----|------------------------------------|----|----------------------------------|---|
| Micro-generator rating per phase (rpp) | | 3.0 | | kW | | |
| For 3-phase Micro-generators , tick this box if harmonic measurements are identical for all three phases. If the harmonics are not identical for each phase, please replicate this section with the results for each phase. | | | | | | |
| Harmo nic | At 45-55% of Registered Capacity ¹ | | 100% of Registered Capacity | | | |
| | Measured Value MV in Amps | | Measured Value MV in Amps | | Limit in BS EN 61000-3-2 in Amps | Higher limit for odd harmonics 21 and above |
| 2 | 0.022 | | 0.030 | | 1.080 | |
| 3 | 0.019 | | 0.029 | | 2.300 | |
| 4 | 0.008 | | 0.013 | | 0.430 | |
| 5 | 0.010 | | 0.009 | | 1.140 | |
| 6 | 0.007 | | 0.007 | | 0.300 | |
| 7 | 0.015 | | 0.017 | | 0.770 | |
| 8 | 0.006 | | 0.007 | | 0.230 | |
| 9 | 0.021 | | 0.026 | | 0.400 | |
| 10 | 0.006 | | 0.006 | | 0.184 | |
| 11 | 0.057 | | 0.083 | | 0.330 | |
| 12 | 0.005 | | 0.005 | | 0.153 | |
| 13 | 0.041 | | 0.070 | | 0.210 | |
| 14 | 0.005 | | 0.005 | | 0.131 | |
| 15 | 0.028 | | 0.058 | | 0.150 | |
| 16 | 0.005 | | 0.005 | | 0.115 | |

¹ See the note in A.2.3.1 if 45-55% of **Registered Capacity** is below the minimum stable operating level. If an alternative loading level is chosen, the level should be indicated on the test form and the reason for not testing at 45-55% of **Registered Capacity** should be stated. The additional comments box at the end of the harmonics test sheet can be used for this.

| | | | | | | |
|----|-------|--|-------|--|-------|-------|
| 17 | 0.019 | | 0.048 | | 0.132 | |
| 18 | 0.005 | | 0.005 | | 0.102 | |
| 19 | 0.013 | | 0.040 | | 0.118 | |
| 20 | 0.005 | | 0.005 | | 0.092 | |
| 21 | 0.008 | | 0.033 | | 0.107 | 0.160 |
| 22 | 0.005 | | 0.005 | | 0.084 | |
| 23 | 0.006 | | 0.028 | | 0.098 | 0.147 |
| 24 | 0.005 | | 0.005 | | 0.077 | |
| 25 | 0.005 | | 0.023 | | 0.090 | 0.135 |
| 26 | 0.005 | | 0.005 | | 0.071 | |
| 27 | 0.005 | | 0.020 | | 0.083 | 0.124 |
| 28 | 0.005 | | 0.005 | | 0.066 | |
| 29 | 0.005 | | 0.017 | | 0.078 | 0.117 |
| 30 | 0.004 | | 0.005 | | 0.061 | |
| 31 | 0.005 | | 0.014 | | 0.073 | 0.109 |
| 32 | 0.005 | | 0.004 | | 0.058 | |
| 33 | 0.005 | | 0.013 | | 0.068 | 0.102 |
| 34 | 0.005 | | 0.005 | | 0.054 | |
| 35 | 0.004 | | 0.011 | | 0.064 | 0.096 |
| 36 | 0.006 | | 0.005 | | 0.051 | |
| 37 | 0.004 | | 0.010 | | 0.061 | 0.091 |
| 38 | 0.006 | | 0.005 | | 0.048 | |
| 39 | 0.004 | | 0.009 | | 0.058 | 0.087 |
| 40 | 0.006 | | 0.006 | | 0.046 | |

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Additional comments:

3. Power Quality – Voltage fluctuations and Flicker: These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (**Inverter** connected) or Annex A2 A.2.3.3 (Synchronous).

The standard test impedance is 0.4 Ω for a single phase **Micro-generating Plant** (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase **Micro-generating Plant** (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the **Power Factor** of the generation output is 0.98 or above):

$d_{\text{maxnormalised value}} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

The test date and location must be declared.

| | | | | | | | | |
|--|--|---------|------|---------------|-----------|------|-----------------|-------------------------|
| Test start date | 2024.8.21 | | | Test end date | 2024.8.29 | | | |
| Test location | test lab of GoodWe Technologies Co., Ltd (No.90 Zijin Rd., New District, Suzhou, 215011, China) | | | | | | | |
| | Starting | | | Stopping | | | Running | |
| | d(max) | d(c) | d(t) | d(max) | d(c) | d(t) | P _{st} | P _{lt} 2 hours |
| Measured Values at test impedance | 0.189 % | 0.086 % | 0.0% | 0.187% | 0.074% | 0.0% | 0.120 | 0.122 |
| Normalised to standard impedance | 0.189 % | 0.086 % | 0.0% | 0.187% | 0.074% | 0.0% | 0.120 | 0.122 |
| Normalised to required maximum impedance | NA | NA | NA | NA | NA | NA | NA | NA |
| Limits set under BS EN 61000-3-11 | 4% | 3.3% | 3.3% | 4% | 3.3% | 3.3% | 1.0 | 0.65 |

| Test Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
|--------------------|---|-----------------|----------|---|------------------|----------|
| Standard Impedance | R | 0.24 * 0.4 ^ | Ω | X | 0.15 * 0.25 ^ | Ω |
| Maximum Impedance | R | NA | Ω | X | NA | Ω |

*Applies to three phase and split single phase **Micro-generators**. Delete as appropriate.

^ Applies to single phase **Micro-generators** and **Micro-generators** using two phases on a three phase system. Delete as appropriate.

4. Power quality – DC injection: This test should be carried out in accordance with A 1.3.4 as applicable.

The % **DC** injection (“as % of rated AC current” below) is calculated as follows:

% **DC** injection = Recorded **DC** value in Amps / base current

where the base current is the **Registered Capacity** (W) / 230 V. The % **DC** injection should not be greater than 0.25%.

| | | | | |
|----------------------------------|---------|---------|---------|---------|
| Test power level | 20% | 50% | 75% | 100% |
| Recorded DC value in Amps | 0.0140A | 0.0161A | 0.0151A | 0.0160A |
| as % of rated AC current | 0.107% | 0.123% | 0.115% | 0.123% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |

5. Power Quality – Power factor: This test shall be carried out in accordance with A.1.3.2 and A.2.3.2 at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.

| | | | |
|---------------------------|---------|-------|-------|
| | 216.2 V | 230 V | 253 V |
| Measured value | 0.987 | 0.988 | 0.984 |
| Power Factor Limit | >0.95 | >0.95 | >0.95 |

6. Protection – Frequency tests: These tests should be carried out in accordance with Annex A1 A.1.2.3 (**Inverter** connected) or Annex A2 A.2.2.3 (Synchronous). For trip tests, frequency and time delay should be stated. For “no trip tests”, “no trip” can be stated.

| | | | |
|----------|---------|-----------|-----------------|
| Function | Setting | Trip test | “No trip tests” |
|----------|---------|-----------|-----------------|

| | Frequency | Time delay | Frequency | Time delay | Frequency /time | Confirm no trip |
|-------------|-----------|------------|-----------|------------|--------------------|-----------------|
| U/F stage 1 | 47.5 Hz | 20 s | 47.48 Hz | 20.06s | 47.7 Hz 30 s | no trip |
| U/F stage 2 | 47 Hz | 0.5 s | 46.90 Hz | 0.51s | 47.2 Hz 19.5 s | no trip |
| | | | | | 46.8 Hz 0.45 s | no trip |
| O/F stage 1 | 52 Hz | 0.5 s | 52.02 Hz | 0.56s | 51.8 Hz 120.0 s | no trip |
| | | | | | 52.2 Hz 0.45 s | no trip |

Note. For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the protection can be used. The "No trip tests" need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

7. Protection – Voltage tests: These tests should be carried out in accordance with Annex A1 A.1.2.2 (Inverter connected) or Annex A2 A.2.2.2 (Synchronous). For trip tests, voltage and time delay should be stated. For "no trip tests", "no trip" can be stated.

| Function | Setting | | Trip test | | "No trip tests" | |
|-------------|---------|------------|-----------|------------|-------------------|-----------------|
| | Voltage | Time delay | Voltage | Time delay | Voltage /time | Confirm no trip |
| U/V | 184 V | 2.5 s | 183.5V | 2.50s | 188 V 5.0 s | no trip |
| | | | | | 180 V 2.45 s | no trip |
| O/V stage 1 | 262.2 V | 1.0 s | 265.0V | 1.01s | 258.2 V 5.0 s | no trip |
| O/V stage 2 | 273.7 V | 0.5 s | 277.0V | 0.50s | 269.7 V 0.95 s | no trip |
| | | | | | 277.7 V 0.45 s | no trip |

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

8. Protection – Loss of Mains test: For PV Inverters shall be tested in accordance with BS EN 62116. Other Micro-generators should be tested in accordance with A.2.2.4 at 10%, 55% and 100% of rated power.

To be carried out at three output power levels with a tolerance of plus or minus 5% in Test Power levels.²

² See the note in A.2.2.4 if the suggested loading levels are below the minimum stable operating level. If alternative loading levels are chosen, the level should be indicated on the test form and the reason for not testing at 10%/55% of **Registered Capacity** should be stated. The additional comments box at the end of the loss of mains test sheet can be used for this.

| | | | | | | |
|---|-----------------------------------|-----------------------------------|-----------------------------------|------------------------------------|------------------------------------|------------------------------------|
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Limit is 0.5 s | 0.310s | 0.412s | 0.492s | 0.298s | 0.430s | 0.432s |
| For Multiphase Micro-generators confirm that the device shuts down correctly after the removal of a single fuse as well as operation of all phases. | | | | | | |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph1 fuse removed | NA | NA | NA | NA | NA | NA |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph2 fuse removed | NA | NA | NA | NA | NA | NA |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph3 fuse removed | NA | NA | NA | NA | NA | NA |
| Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies. | | | | | | |
| Indicate additional shut down time included in above results. | | | | NA ms | | |
| Additional comments: | | | | | | |

For **Inverters** tested to BS EN 62116 the following sub set of tests should be recorded in the following table.

| | | | | | | |
|--------------------------|-----|-----|------|-----|-----|------|
| Test Power and imbalance | 33% | 66% | 100% | 33% | 66% | 100% |
|--------------------------|-----|-----|------|-----|-----|------|

| | -5% Q Test 22 | -5% Q Test 12 | -5% P Test 5 | +5% Q Test 31 | +5% Q Test 21 | +5% P Test 10 |
|--|------------------|------------------|-----------------|------------------|------------------|------------------|
| Trip time. Limit is 0.5 s ³ | 0.309s | 0.478s | 0.393s | 0.260s | 0.410s | 0.468s |

9. Protection – Frequency change, Vector Shift Stability test: This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 (**Inverter** connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the **Micro-generating Plant** does not trip under positive / negative vector shift.

| | Start Frequency | Change | Confirm no trip |
|-----------------------|-----------------|--------------|-----------------|
| Positive Vector Shift | 49.0 Hz | +50 degrees | no trip |
| Negative Vector Shift | 50.0 Hz | - 50 degrees | no trip |

10. Protection – Frequency change, RoCoF Stability test: The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 (**Inverter** connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the **Micro-generating Plant** does not trip for the duration of the ramp up and ramp down test.

| Ramp range | Test frequency ramp: | Test Duration | Confirm no trip |
|--------------------|-------------------------|---------------|-----------------|
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | 2.1 s | no trip |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | 2.1 s | no trip |

11. Limited Frequency Sensitive Mode – Overfrequency test: This test should be carried out in accordance with A.1.2.8. The test should be carried out using the specific threshold frequency of 50.4 Hz and **Droop** of 10%. The measurement tolerances are contained in A.1.2.8.

| Test sequence at Registered Capacity >80% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop(%) |
|---|---|-----------|----------------------|---|
| Step a) 50.00 Hz ±0.01 Hz | 3077 | 50 | 3077 | / |
| Step b) 50.45 Hz ±0.05 Hz | 3038 | 50.45 | | / |
| Step c) 50.70 Hz ±0.10 Hz | 2873 | 50.7 | | 9.09% |
| Step d) 51.15 Hz ±0.05 Hz | 2576 | 51.15 | | 9.33% |
| Step e) 50.70 Hz ±0.10 Hz | 2873 | 50.7 | | 9.09% |
| Step f) 50.45 Hz ±0.05 Hz | 3038 | 50.45 | | / |
| Step g) 50.00 Hz ±0.01 Hz | 3076 | 50 | | / |

³ If the device requires additional shut down time (beyond 0.5s but less than 1s) then this should be stated on this form.

| Test sequence at Registered Capacity 40% - 60% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop(%) |
|--|---|-----------|----------------------|---|
| Step a) 50.00 Hz ± 0.01 Hz | 1541 | 50 | 1541 | / |
| Step b) 50.45 Hz ± 0.05 Hz | 1497 | 50.45 | | / |
| Step c) 50.70 Hz ± 0.10 Hz | 1332 | 50.7 | | 9.09% |
| Step d) 51.15 Hz ± 0.05 Hz | 1034 | 51.15 | | 9.06% |
| Step e) 50.70 Hz ± 0.10 Hz | 1332 | 50.7 | | 9.09% |
| Step f) 50.45 Hz ± 0.05 Hz | 1497 | 50.45 | | / |
| Step g) 50.00 Hz ± 0.01 Hz | 1541 | 50 | | / |

12. Power output with falling frequency test: This test should be carried out in accordance with A.1.2.7.

| Test sequence | Measured Active Power Output | Frequency | Primary power source |
|---|-------------------------------------|-----------|----------------------|
| Test a) 50 Hz ± 0.01 Hz | 3081 | 50 | 3081 |
| Test b) Point between 49.5 Hz and 49.6 Hz | 3080 | 49.55 | 3081 |
| Test c) Point between 47.5 Hz and 47.6 Hz | 3080 | 47.55 | 3081 |

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

13. Re-connection timer.

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the **Micro-generating Plant** does not reconnect at the voltage and frequency settings below; a statement of "no reconnection" can be made.

| Time delay setting | Measured delay | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 2. | | | | |
|---|----------------|---|------------------|------------------|------------------|--|
| 48s | 48s | At 266.2 V | At 180.0 V | At 47.4 Hz | At 52.1 Hz | |
| Confirmation that the Micro-generator does not re-connect. | | No re-connection | no re-connection | no re-connection | no re-connection | |

14. Fault level contribution: These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 (**Inverter** connected) and Annex A2 A.2.3.4 (Synchronous). Please complete each entry, even if the fault contribution is zero.

| | |
|---|----------------------------|
| For machines with electro-magnetic output | For Inverter output |
|---|----------------------------|

| Parameter | Symbol | Value | Time after fault | Volts | Amps |
|--|----------|-------|------------------|-------|------------|
| Peak Short Circuit current | i_p | NA | 20 ms | 61.8 | 14.2 |
| Initial Value of aperiodic current | A | NA | 100 ms | 53.0 | 14.8 |
| Initial symmetrical short-circuit current* | I_k | NA | 250 ms | 50.6 | 14.4 |
| Decaying (aperiodic) component of short circuit current* | i_{DC} | NA | 500 ms | 49.9 | 14.2 |
| Reactance/Resistance Ratio of source* | X/R | NA | Time to trip | 2.49 | In seconds |
| <p>For rotating machines and linear piston machines the test should produce a 0 s – 2 s plot of the short circuit current as seen at the Micro-generator terminals.</p> <p>* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot</p> | | | | | |
| Logic Interface (input port) | | | | | |
| Confirm that an input port is provided and can be used to reduce the Active Power output to zero | | | | | Yes |
| Provide high level description of logic interface, e.g. details in 9.4.3 such as AC or DC signal (the additional comments box below can be used) | | | | | Yes |
| Self-Monitoring solid state switching: No specified test requirements. Refer to EREC G98 Annex A1 A.1.3.6 (Inverter connected). | | | | | Yes |
| It has been verified that in the event of the solid state switching device failing to disconnect the Micro-generator , the voltage on the output side of the switching device is reduced to a value below 50 V within 0.5 s. | | | | | |
| Cyber security | | | | | |
| Confirm that the Manufacturer or Installer of the Micro-generator has provided a statement describing how the Micro-generator has been designed to comply with cyber security requirements, as detailed in 9.7. | | | | | Yes |
| Additional comments | | | | | |
| <p>The following documents are attached to this declaration:</p> <ul style="list-style-type: none"> - “declaration about Logic Interface”, as for required in “Logic Interface” section; - “declaration about cyber-security”, as for required in “Cyber security” section; | | | | | |

Form C: Type Test Verification Report

All Micro-generators connected to the **DNO Distribution Network** shall be **Fully Type Tested**. This form is the **Manufacturer's** declaration of compliance with the requirements of EREC G98.

This form should be used when making a Type Test submission to the Energy Networks Association (ENA) Type Test Register.

If the **Micro-generator** is **Fully Type Tested** and already registered with the ENA Type Test Register, the **Installation Document** should include the **Manufacturer's** Reference Number (the system reference), and this form does not need to be submitted.

| | | | |
|--|--|---|---|
| Manufacturer's reference number | | Clearline Inverter GW3600-DNS-30 | |
| Micro-generator technology | | DNS G3 Grid-Connected PV Inverter (Inverter Models:GW3600-DNS-30) | |
| Manufacturer name | | Viridian Solar Limited | |
| Address | | 68 Stirling Way, Papworth, Cambridge CB23 3GY, UK | |
| Tel | +44 (0)1480 839 865 | Fax | N/A |
| E-mail | info@viridiansolar.co.uk | Web site | www.viridiansolar.co.uk |
| Registered Capacity , use separate sheet if more than one connection option. | Connection Option | | |
| | 3.6 | kW single phase, single, split or three phase system | |
| | / | kW three phase | |
| | / | kW two phases in three phase system | |
| | / | kW two phases split phase system | |
| Energy storage capacity for Electricity Storage devices | | Not energy storage inverter | |
| Manufacturer Type Test declaration. - I certify that all products supplied by the company with the above Fully Type Tested reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of EREC G98. | | | |
| Signed |  KT Tan 8 th August 2023 | On behalf of |  Viridian Solar Limited |

Note that testing can be done by the **Manufacturer** of an individual component or by an external test house.

Where parts of the testing are carried out by persons or organisations other than the **Manufacturer** then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.

1. Operating Range: This test should be carried out as specified in A.1.2.10.

Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.

Test 1


Voltage = 85% of nominal (195.5 V)

Frequency = 47.0 Hz

Power factor = 1

Period of test 20 seconds

Result: Pass



Test 2


Voltage = 85% of nominal (195.5 V)

Frequency = 47.5 Hz

Power factor = 1

Period of test 90 minutes

Result: Pass



Test 3


Voltage = 110% of nominal (253 V).

Frequency = 51.5 Hz

Power factor = 1

Period of test 90 minutes

Result: Pass



Test 4


Voltage = 110% of nominal (253 V).



Frequency = 52.0 Hz

Power factor = 1

Period of test 15 minutes

Result: Pass



| | |
|--|---|
| <p>Test 5</p> <p>Voltage = 100% of nominal (230 V).</p> <p>Frequency = 50.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p> | <p>Result:Pass</p>  |
| <p>Test 6 RoCoF withstand</p> <p>Confirm that the Micro-Generating Plant is capable of staying connected to the Distribution Network and operate at rates of change of frequency up to 1 Hzs⁻¹ as measured over a period of 500 ms.</p> | <p>Result:Pass</p>  |

2.Power Quality – Harmonics: These tests should be carried out as specified in BS EN 61000-3-2. The chosen test should be undertaken with a fixed source of energy at two power levels a) between 45 and 55% and b) at 100% of **Registered Capacity**. The test requirements are specified in Annex A1 A.1.3.1 (**Inverter** connected) or Annex A2 A.2.3.1 (Synchronous).

Micro-generator tested to BS EN 61000-3-2

Micro-generator rating per phase
(rpp)

3.6

kW

For 3-phase **Micro-generators**, tick this box if harmonic measurements are identical for all three phases. If the harmonics are not identical for each phase, please replicate this section with the results for each phase.

| Harmo nic | At 45-55% of Registered Capacity ¹ | | 100% of Registered Capacity | | | |
|--------------|---|--|--|--|--|--|
| | Measured Value MV in Amps | | Measured Value MV in Amps | | Limit in BS EN 61000-3-2 in Amps | Higher limit for odd harmonics 21 and above |
| 2 | 0.022 | | 0.030 | | 1.080 | |
| 3 | 0.019 | | 0.029 | | 2.300 | |
| 4 | 0.008 | | 0.012 | | 0.430 | |
| 5 | 0.011 | | 0.007 | | 1.140 | |
| 6 | 0.004 | | 0.008 | | 0.300 | |
| 7 | 0.019 | | 0.020 | | 0.770 | |
| 8 | 0.005 | | 0.008 | | 0.230 | |
| 9 | 0.028 | | 0.033 | | 0.400 | |
| 10 | 0.004 | | 0.007 | | 0.184 | |
| 11 | 0.083 | | 0.109 | | 0.330 | |
| 12 | 0.008 | | 0.007 | | 0.153 | |
| 13 | 0.064 | | 0.098 | | 0.210 | |
| 14 | 0.006 | | 0.006 | | 0.131 | |
| 15 | 0.048 | | 0.084 | | 0.150 | |
| 16 | 0.004 | | 0.005 | | 0.115 | |

¹ See the note in A.2.3.1 if 45-55% of **Registered Capacity** is below the minimum stable operating level. If an alternative loading level is chosen, the level should be indicated on the test form and the reason for not testing at 45-55% of **Registered Capacity** should be stated. The additional comments box at the end of the harmonics test sheet can be used for this.

| | | | | | | |
|----|-------|--|-------|--|-------|-------|
| 17 | 0.034 | | 0.070 | | 0.132 | |
| 18 | 0.005 | | 0.005 | | 0.102 | |
| 19 | 0.023 | | 0.059 | | 0.118 | |
| 20 | 0.005 | | 0.006 | | 0.092 | |
| 21 | 0.015 | | 0.048 | | 0.107 | 0.160 |
| 22 | 0.005 | | 0.006 | | 0.084 | |
| 23 | 0.009 | | 0.039 | | 0.098 | 0.147 |
| 24 | 0.004 | | 0.005 | | 0.077 | |
| 25 | 0.006 | | 0.032 | | 0.090 | 0.135 |
| 26 | 0.004 | | 0.005 | | 0.071 | |
| 27 | 0.004 | | 0.026 | | 0.083 | 0.124 |
| 28 | 0.004 | | 0.005 | | 0.066 | |
| 29 | 0.004 | | 0.022 | | 0.078 | 0.117 |
| 30 | 0.003 | | 0.005 | | 0.061 | |
| 31 | 0.004 | | 0.017 | | 0.073 | 0.109 |
| 32 | 0.004 | | 0.005 | | 0.058 | |
| 33 | 0.004 | | 0.016 | | 0.068 | 0.102 |
| 34 | 0.004 | | 0.005 | | 0.054 | |
| 35 | 0.005 | | 0.013 | | 0.064 | 0.096 |
| 36 | 0.005 | | 0.005 | | 0.051 | |
| 37 | 0.006 | | 0.012 | | 0.061 | 0.091 |
| 38 | 0.010 | | 0.009 | | 0.048 | |
| 39 | 0.010 | | 0.014 | | 0.058 | 0.087 |
| 40 | 0.025 | | 0.025 | | 0.046 | |

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Additional comments:

3.Power Quality – Voltage fluctuations and Flicker: These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (**Inverter** connected) or Annex A2 A.2.3.3 (Synchronous).

The standard test impedance is 0.4 Ω for a single phase **Micro-generating Plant** (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase **Micro-generating Plant** (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the **Power Factor** of the generation output is 0.98 or above):

$d \text{ max normalised value} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

The test date and location must be declared.

| | | | | | | | | |
|--|--|---------|------|---------------|-----------|------|-----------------|-------------------------|
| Test start date | 2022.9.21 | | | Test end date | 2022.9.21 | | | |
| Test location | Test lab of GoodWe Technologies Co., Ltd (No.90 Zijin Rd., New District, Suzhou, 215011, China) | | | | | | | |
| | Starting | | | Stopping | | | Running | |
| | d(max) | d(c) | d(t) | d(max) | d(c) | d(t) | P _{st} | P _{It} 2 hours |
| Measured Values at test impedance | 0.132 % | 0.10 8% | 0.0% | 0.358% | 0.318% | 0.0% | 0.057 | 0.044 |
| Normalised to standard impedance | 0.132 % | 0.10 8% | 0.0% | 0.358% | 0.318% | 0.0% | 0.057 | 0.044 |
| Normalised to required maximum impedance | NA | NA | NA | NA | NA | NA | NA | NA |
| Limits set under BS EN 61000-3-11 | 4% | 3.3% | 3.3% | 4% | 3.3% | 3.3% | 1.0 | 0.65 |

| Test Impedance | R | 0.4 | Ω | X | 0.25 | Ω |
|--------------------|---|-----------------|----------|---|------------------|----------|
| Standard Impedance | R | 0.24 * 0.4 ^ | Ω | X | 0.15 * 0.25 ^ | Ω |
| Maximum Impedance | R | NA | Ω | X | NA | Ω |

*Applies to three phase and split single phase **Micro-generators**. Delete as appropriate.

^ Applies to single phase **Micro-generators** and **Micro-generators** using two phases on a three phase system. Delete as appropriate.

4.Power quality – DC injection: This test should be carried out in accordance with A 1.3.4 as applicable.

The % **DC** injection (“as % of rated AC current” below) is calculated as follows:

% **DC** injection = Recorded **DC** value in Amps / base current

where the base current is the **Registered Capacity** (W) / 230 V. The % **DC** injection should not be greater than 0.25%.

| | | | | |
|----------------------------------|---------|---------|---------|---------|
| Test power level | 20% | 50% | 75% | 100% |
| Recorded DC value in Amps | 0.0143A | 0.0144A | 0.0112A | 0.0124A |
| as % of rated AC current | 0.091% | 0.092% | 0.072% | 0.079% |
| Limit | 0.25% | 0.25% | 0.25% | 0.25% |

5.Power Quality – Power factor: This test shall be carried out in accordance with A.1.3.2 and A.2.3.2 at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.

| | | | |
|---------------------------|---------|--------|--------|
| | 216.2 V | 230 V | 253 V |
| Measured value | 0.9977 | 0.9978 | 0.9978 |
| Power Factor Limit | >0.95 | >0.95 | >0.95 |

6.Protection – Frequency tests: These tests should be carried out in accordance with Annex A1 A.1.2.3 (**Inverter** connected) or Annex A2 A.2.2.3 (Synchronous). For trip tests, frequency and time delay should be stated. For “no trip tests”, “no trip” can be stated.

| | | | |
|----------|---------|-----------|-----------------|
| Function | Setting | Trip test | “No trip tests” |
|----------|---------|-----------|-----------------|

| | Frequency | Time delay | Frequency | Time delay | Frequency /time | Confirm no trip |
|-------------|-----------|------------|-----------|------------|--------------------|-----------------|
| U/F stage 1 | 47.5 Hz | 20 s | 47.48 Hz | 20.05s | 47.7 Hz 30 s | no trip |
| U/F stage 2 | 47 Hz | 0.5 s | 46.98 Hz | 0.52s | 47.2 Hz 19.5 s | no trip |
| | | | | | 46.8 Hz 0.45 s | no trip |
| O/F stage 1 | 52 Hz | 0.5 s | 52.02 Hz | 0.52s | 51.8 Hz 120.0 s | no trip |
| | | | | | 52.2 Hz 0.45 s | no trip |

Note. For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the protection can be used. The “No trip tests” need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

7. Protection – Voltage tests: These tests should be carried out in accordance with Annex A1 A.1.2.2 (Inverter connected) or Annex A2 A.2.2.2 (Synchronous). For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

| Function | Setting | | Trip test | | “No trip tests” | |
|-------------|---------|------------|-----------|------------|-------------------|-----------------|
| | Voltage | Time delay | Voltage | Time delay | Voltage /time | Confirm no trip |
| U/V | 184 V | 2.5 s | 183.55V | 2.52s | 188 V 5.0 s | no trip |
| | | | | | 180 V 2.45 s | no trip |
| O/V stage 1 | 262.2 V | 1.0 s | 262.13V | 1.02s | 258.2 V 5.0 s | no trip |
| O/V stage 2 | 273.7 V | 0.5 s | 274.15 | 0.52s | 269.7 V 0.95 s | no trip |
| | | | | | 277.7 V 0.45 s | no trip |

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

8. Protection – Loss of Mains test: For PV Inverters shall be tested in accordance with BS EN 62116. Other Micro-generators should be tested in accordance with A.2.2.4 at 10%, 55% and 100% of rated power.

To be carried out at three output power levels with a tolerance of plus or minus 5% in Test Power levels.²

² See the note in A.2.2.4 if the suggested loading levels are below the minimum stable operating level. If alternative loading levels are chosen, the level should be indicated on the test form and the reason for not testing at 10%/55% of **Registered Capacity** should be stated. The additional comments box at the end of the loss of mains test sheet can be used for this.

| | | | | | | |
|---|-----------------------------------|-----------------------------------|-----------------------------------|------------------------------------|------------------------------------|------------------------------------|
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Limit is 0.5 s | NA | NA | NA | NA | NA | NA |
| For Multi phase Micro-generators confirm that the device shuts down correctly after the removal of a single fuse as well as operation of all phases. | | | | | | |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph1 fuse removed | NA | NA | NA | NA | NA | NA |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph2 fuse removed | NA | NA | NA | NA | NA | NA |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Registered Capacity | 95% of Registered Capacity | 95% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity | 105% of Registered Capacity |
| Trip time. Ph3 fuse removed | NA | NA | NA | NA | NA | NA |
| Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies. | | | | | | |
| Indicate additional shut down time included in above results. | | | | NA ms | | |
| Additional comments: | | | | | | |

For **Inverters** tested to BS EN 62116 the following sub set of tests should be recorded in the following table.

| | | | | | | |
|--------------------------|-----|-----|------|-----|-----|------|
| Test Power and imbalance | 33% | 66% | 100% | 33% | 66% | 100% |
|--------------------------|-----|-----|------|-----|-----|------|

| | | | | | | |
|--|-------------------------------------|------------------|----------------------|--|------------------|------------------|
| | -5% Q Test 22 | -5% Q Test 12 | -5% P Test 5 | +5% Q Test 31 | +5% Q Test 21 | +5% P Test 10 |
| Trip time. Limit is 0.5 s ³ | 0.470s | 0.400s | 0.420s | 0.470s | 0.490s | 0.410s |
| 9.Protection – Frequency change, Vector Shift Stability test: This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the Micro-generating Plant does not trip under positive / negative vector shift. | | | | | | |
| | Start Frequency | Change | Confirm no trip | | | |
| Positive Vector Shift | 49.0 Hz | +50 degrees | no trip | | | |
| Negative Vector Shift | 50.0 Hz | - 50 degrees | no trip | | | |
| 10.Protection – Frequency change, RoCoF Stability test: The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the Micro-generating Plant does not trip for the duration of the ramp up and ramp down test. | | | | | | |
| Ramp range | Test frequency ramp: | Test Duration | Confirm no trip | | | |
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | 2.1 s | no trip | | | |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | 2.1 s | no trip | | | |
| 11.Limited Frequency Sensitive Mode – Over frequency test: This test should be carried out in accordance with A.1.2.8. The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. The measurement tolerances are contained in A.1.2.8. | | | | | | |
| Test sequence at Registered Capacity >80% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop (%) | | |
| Step a) 50.00 Hz ±0.01 Hz | 3598 | 50 | 3681 | / | | |
| Step b) 50.45 Hz ±0.05 Hz | 3559 | 50.45 | | 9.23% | | |
| Step c) 50.70 Hz ±0.10 Hz | 3361 | 50.7 | | 9.11% | | |
| Step d) 51.15 Hz ±0.05 Hz | 3007 | 51.15 | | 9.14% | | |
| Step e) 50.70 Hz ±0.10 Hz | 3357 | 50.7 | | 8.96% | | |
| Step f) 50.45 Hz ±0.05 Hz | 3568 | 50.45 | | 12.00% | | |
| Step g) 50.00 Hz ±0.01 Hz | 3604 | 50 | | / | | |

³ If the device requires additional shut down time (beyond 0.5s but less than 1s) then this should be stated on this form.

| Test sequence at Registered Capacity 40% - 60% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop(%) |
|--|------------------------------|-----------|----------------------|--------------------------------|
| Step a) 50.00 Hz ± 0.01 Hz | 1805 | 50 | 1835 | / |
| Step b) 50.45 Hz ± 0.05 Hz | 1766 | 50.45 | | 9.23% |
| Step c) 50.70 Hz ± 0.10 Hz | 1568 | 50.7 | | 9.11% |
| Step d) 51.15 Hz ± 0.05 Hz | 1212 | 51.15 | | 9.11% |
| Step e) 50.70 Hz ± 0.10 Hz | 1568 | 50.7 | | 9.11% |
| Step f) 50.45 Hz ± 0.05 Hz | 1767 | 50.45 | | 9.47% |
| Step g) 50.00 Hz ± 0.01 Hz | 1801 | 50 | | / |

12. Power output with falling frequency test: This test should be carried out in accordance with A.1.2.7.

| Test sequence | Measured Active Power Output | Frequency | Primary power source |
|---|-------------------------------------|-----------|----------------------|
| Test a) 50 Hz ± 0.01 Hz | 3601 | 50 | 3681 |
| Test b) Point between 49.5 Hz and 49.6 Hz | 3599 | 49.55 | 3680 |
| Test c) Point between 47.5 Hz and 47.6 Hz | 3598 | 47.55 | 3680 |

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

13. Re-connection timer.

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the **Micro-generating Plant** does not reconnect at the voltage and frequency settings below; a statement of "no reconnection" can be made.

| Time delay setting | Measured delay | | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 2. | | | |
|---|----------------|--|---|------------------|------------------|------------------|
| 48s | 48s | | At 266.2 V | At 180.0 V | At 47.4 Hz | At 52.1 Hz |
| Confirmation that the Micro-generator does not re-connect. | | | No re-connection | no re-connection | no re-connection | no re-connection |

14. Fault level contribution: These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 (**Inverter** connected) and Annex A2 A.2.3.4 (Synchronous). Please complete each entry, even if the fault contribution is zero.

| | |
|---|----------------------------|
| For machines with electro-magnetic output | For Inverter output |
|---|----------------------------|

| Parameter | Symbol | Value | Time after fault | Volts | Amps |
|---|----------|-------|------------------|-------|------------|
| Peak Short Circuit current | i_p | NA | 20 ms | 33 | 17.29 |
| Initial Value of aperiodic current | A | NA | 100 ms | 32.6 | 18.4 |
| Initial symmetrical short-circuit current* | I_k | NA | 250 ms | 32.8 | 17.76 |
| Decaying (aperiodic) component of short circuit current* | i_{DC} | NA | 500 ms | 33 | 17.45 |
| Reactance/Resistance Ratio of source* | X/R | NA | Time to trip | 2.75 | In seconds |
| For rotating machines and linear piston machines the test should produce a 0 s – 2 s plot of the short circuit current as seen at the Micro-generator terminals. | | | | | |
| * Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot | | | | | |
| Logic Interface (input port) | | | | | |
| Confirm that an input port is provided and can be used to reduce the Active Power output to zero | | | | | Yes |
| Provide high level description of logic interface, e.g. details in 9.4.3 such as AC or DC signal (the additional comments box below can be used) | | | | | Yes |
| Self-Monitoring solid state switching: No specified test requirements. Refer to EREC G98 Annex A1 A.1.3.6 (Inverter connected). | | | | | Yes |
| It has been verified that in the event of the solid state switching device failing to disconnect the Micro-generator , the voltage on the output side of the switching device is reduced to a value below 50 V within 0.5 s. | | | | | |
| Cyber security | | | | | |
| Confirm that the Manufacturer or Installer of the Micro-generator has provided a statement describing how the Micro-generator has been designed to comply with cyber security requirements, as detailed in 9.7. | | | | | Yes |
| Additional comments | | | | | |
| The following documents are attached to this declaration: - “Clearline Inverters DNS declaration about Logic Interface”, as for required in “Logic Interface” section. - “Clearline Inverters DNS declaration about cyber-security”, as for required in “Cyber security” section; | | | | | |

Form A2-3: Compliance Verification Report for Type A Inverter Connected Power Generating Modules

This form should be used by the **Manufacturer** to demonstrate and declare compliance with the requirements of EREC G99. The form can be used in a variety of ways as detailed below:

1. To obtain **Fully Type Tested** status (≤ 50 kW)

The **Manufacturer** can use this form to obtain **Fully Type Tested** status for a **Power Generating Module** by registering this completed form with the Energy Networks Association (ENA) Type Test Verification Report Register. Tests 1 – 15 must all be completed and compliant for the **Power Generating Module** to be classified as **Fully Type Tested**.

2. To obtain **Type Tested** status for a product

This form can be used by the **Manufacturer** to obtain **Type Tested** status for a product which is used in a **Power Generating Module** by registering this form with the relevant parts completed with the Energy Networks Association (ENA) Type Test Verification Report Register.

Where the **Manufacturer** is seeking to obtain **Type Tested** status for an **Interface Protection** device the appropriate section of Form A2-4 should be used.

3. One-off Installation

This form can be used by the **Manufacturer** or **Installer** to confirm that the **Power Generating Module** has been tested to satisfy all or part of the requirements of this EREC G99. This form shall be submitted to the **DNO** as part of the application.

A combination of (2) and (3) can be used as required, together with Form A2-4 where compliance of the **Interface Protection** is to be demonstrated on site.

Note:

Within this Form A2-3 the term **Power Park Module** will be used but its meaning can be interpreted within Form A2-3 to mean **Power Park Module**, **Generating Unit** or **Inverter** as appropriate for the context. However, note that compliance shall be demonstrated at the **Power Park Module** level.

If the **Power Generating Module** is **Fully Type Tested** and registered with the Energy Networks Association (ENA) Type Test Verification Report Register, the Installation Document (Form A3-1 or A3-2) should include the **Manufacturer's** reference number (the system reference), and this form does not need to be submitted.

Where the **Power Generating Module** is not registered with the ENA Type Test Verification Report Register or is not **Fully Type Tested** this form (all or in parts as applicable) needs to be completed and provided to the **DNO**, to confirm that the **Power Generating Module** has been tested to satisfy all or part of the requirements of this EREC G99.

| | | | |
|--|--------------------------|---|-------------------------|
| PGM technology | | DNS G3 Grid-Connected PV Inverter (Inverter Models: Clearline Inverter GW5000-DNS-30) | |
| Manufacturer name | | Viridian Solar Limited | |
| Address | | 68 Stirling Way, Papworth, Cambridge CB23 3GY, UK | |
| Tel | +44 (0)1480 839 865 | Web site | www.viridiansolar.co.uk |
| E-mail | info@viridiansolar.co.uk | | |
| Registered Capacity | | 5kW | |
| Energy storage capacity for Electricity Storage devices | | Not energy storage inverter | |

There are four options for Testing: (1) **Fully Type Tested** (≤ 50 kW), (2) **Type Tested** product, (3) one-off installation, (4) tested on site at time of commissioning. The check box below indicates which tests in this Form have been completed for each of the options. With the exception of **Fully Type Tested PGMs** tests may be carried out at the time of commissioning (Form A4). **Type Tested** status is suitable for devices > 50 kW where the power quality aspects need consideration on a site by site basis in accordance with EREC G5 and EREC P28.
Insert Document reference(s) for **Manufacturers' Information**

| Tested option: | 1. Fully Type Tested | 2. Type Tested product | 3. One-off Manufacturers' Info. | 4. Tested on Site at time of Commissioning |
|---|----------------------|------------------------|---------------------------------|--|
| 0. Fully Type Tested - all tests detailed below completed and evidence attached to this submission | YES | N/A | N/A | N/A |
| 1. Operating Range | N/A | | | |
| 2. PQ – Harmonics | | | | |
| 3. PQ – Voltage Fluctuation and Flicker | | | | |
| 4. PQ – DC Injection (Power Park Modules only) | | | | |
| 5. Power Factor (PF) | | | | |
| 6. Frequency protection trip and ride through tests | | | | |
| 7. Voltage protection trip and ride through tests | | | | |
| 8. Protection – Loss of Mains Test, Vector Shift and RoCoF Stability Test | | | | |
| 9. LFSM-O Test | | | | |
| 10. Protection – Reconnection Timer | | | | |
| 11. Fault Level Contribution | | | | |
| 12. Self-monitoring Solid State Switch | | | | |

There are four options for Testing: (1) **Fully Type Tested** (≤ 50 kW), (2) **Type Tested** product, (3) one-off installation, (4) tested on site at time of commissioning. The check box below indicates which tests in this Form have been completed for each of the options. With the exception of **Fully Type Tested PGMs** tests may be carried out at the time of commissioning (Form A4). **Type Tested** status is suitable for devices > 50 kW where the power quality aspects need consideration on a site by site basis in accordance with EREC G5 and EREC P28.

Insert Document reference(s) for **Manufacturers' Information**

| Tested option: | 1. Fully Type Tested | 2. Type Tested product | 3. One-off Manufacturers' Info. | 4. Tested on Site at time of Commissioning |
|---|----------------------|------------------------|---------------------------------|--|
| 13. Wiring functional tests if required by para 15.2.1 (attach relevant schedule of tests) | | | | |
| 14. Logic Interface (input port) | | | | |
| 15. Cyber security | | | | |

Manufacturer compliance declaration. - I certify that all products supplied by the company with the above **Type Tested Manufacturer's** reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site **Modifications** are required to ensure that the product meets all the requirements of EREC G99.

| | | | |
|--------|--|--------------|--|
| Signed |  KT Tan 6 th July 2023 | On behalf of |  Viridian Solar Limited |
|--------|--|--------------|--|

Note that testing can be done by the **Manufacturer** of an individual component or by an external test house.

Where parts of the testing are carried out by persons or organisations other than the **Manufacturer** then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.

A2-3 Compliance Verification Report –Tests for Type A Inverter Connected Power Generating Modules – test record

1. Operating Range: Tests should be carried with the **Power Generating Module** operating at **Registered Capacity** and connected to a suitable test supply or grid simulation set. The power supplied by the primary source shall be kept stable within $\pm 5\%$ of the apparent power value set for the entire duration of each test sequence.

Frequency, voltage and **Active Power** measurements at the output terminals of the **Power Generating Module** shall be recorded every second. The tests will verify that the **Power Generating Module** can operate within the required ranges for the specified period of time.

The **Interface Protection** shall be disabled during the tests.

In case of a PV **Power Park Module** the PV primary source may be replaced by a DC source.

In case of a full converter **Power Park Module** (eg wind) the primary source and the prime mover **Inverter/rectifier** may be replaced by a DC source.


Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.

Note that the value of voltage stated in brackets assumes a **LV** connection. This should be adjusted for **HV** as required.

Test 1

Voltage = 85% of nominal (195.5 V),
Frequency = 47 Hz,
Power Factor = 1,
Period of test 20 s


Test results : Pass



Test 2

Voltage = 85% of nominal (195.5 V),
Frequency = 47.5 Hz,
Power Factor = 1,
Period of test 90 minutes


Test results : Pass






Test 3

Voltage = 110% of nominal (253 V).,
Frequency = 51.5 Hz,
Power Factor = 1,
Period of test 90 minutes

Test results : Pass



| | |
|--|---|
| <p>Test 4</p> <p>Voltage = 110% of nominal (253 V), Frequency = 52.0 Hz, Power Factor = 1, Period of test 15 minutes</p> | <p>Test results : Pass</p>  |
| <p>Test 5</p> <p>Voltage = 100% of nominal (230 V), Frequency = 50.0 Hz, Power Factor = 1, Period of test = 90 minutes</p> | <p>Test results : Pass</p>  |
| <p>Test 6 RoCoF withstand</p> <p>Confirm that the Power Generating Module is capable of staying connected to the Distribution Network and operate at rates of change of frequency up to 1 Hzs⁻¹ as measured over a period of 500 ms. Note that this is not expected to be demonstrated on site.</p> | <p>Test results : Pass</p>  |

2. Power Quality – Harmonics:

For **Power Generating Modules** of **Registered Capacity** of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12, and measurements for the 2nd – 13th harmonics should be provided. The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 61000-3-12 for three phase equipment. For three phase **Power Generating Modules**, measurements for all phases should be provided.

For **Power Generating Modules** of **Registered Capacity** of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC G5.

The rating of the **Power Generating Module** (per phase) should be provided below, and the Total Harmonic Distortion (THD) and Partial Weighted Harmonic Distortion (PWhd) should be provided at the bottom of this section.

Power Generating Module tested to BS EN 61000-3-12

| | | | | | | | | |
|---|---|----|----|--------------------------|----|-----|---|------------|
| Power Generating Module rating per phase (rpp) | | | | 5 | | kVA | Harmonic % = Measured Value (A) x 23/rating per phase (kVA) | |
| Single or three phase measurements (for single phase measurements, only complete L1 columns below). | | | | Singlephase | | | | |
| Harmonic | At 45-55% of Registered Capacity | | | | | | Limit in BS EN 61000-3-12 | |
| | Measured Value (MV) in Amps | | | Measured Value (MV) in % | | | | |
| | L1 | L2 | L3 | L1 | L2 | L3 | 1 phase | 3 phase |
| 2 | 0.0342 | NA | NA | 0.16 | NA | NA | 8% | 8% |
| 3 | 0.0466 | NA | NA | 0.21 | NA | NA | 21.6% | Not stated |
| 4 | 0.0218 | NA | NA | 0.10 | NA | NA | 4% | 4% |
| 5 | 0.0168 | NA | NA | 0.08 | NA | NA | 10.7% | 10.7% |
| 6 | 0.0150 | NA | NA | 0.07 | NA | NA | 2.67% | 2.67% |
| 7 | 0.0234 | NA | NA | 0.11 | NA | NA | 7.2% | 7.2% |
| 8 | 0.0105 | NA | NA | 0.05 | NA | NA | 2% | 2% |
| 9 | 0.0349 | NA | NA | 0.16 | NA | NA | 3.8% | Not stated |
| 10 | 0.0090 | NA | NA | 0.04 | NA | NA | 1.6% | 1.6% |
| 11 | 0.1207 | NA | NA | 0.56 | NA | NA | 3.1% | 3.1% |
| 12 | 0.0088 | NA | NA | 0.04 | NA | NA | 1.33% | 1.33% |
| 13 | 0.1144 | NA | NA | 0.53 | NA | NA | 2% | 2% |
| THD1 | NA | NA | NA | 1.34 | NA | NA | 23% | 13% |
| PWHD2 | NA | NA | NA | 2.19 | NA | NA | 23% | 22% |
| Harmonic | At 100% of Registered Capacity | | | | | | Limit in BS EN 61000-3-12 | |
| | Measured value (MV) in Amps | | | Measured value (MV) in % | | | | |
| | L1 | L2 | L3 | L1 | L2 | L3 | 1 phase | 3 phase |
| 2 | 0.0125 | NA | NA | 0.06 | NA | NA | 8% | 8% |
| 3 | 0.0217 | NA | NA | 0.10 | NA | NA | 21.6% | Not stated |

¹ THD = Total Harmonic Distortion

² PWHD = Partial Weighted Harmonic Distortion

| | | | | | | | | |
|-------|--------|----|----|------|----|----|-------|------------|
| 4 | 0.0089 | NA | NA | 0.04 | NA | NA | 4% | 4% |
| 5 | 0.0085 | NA | NA | 0.04 | NA | NA | 10.7% | 10.7% |
| 6 | 0.0052 | NA | NA | 0.02 | NA | NA | 2.67% | 2.67% |
| 7 | 0.0198 | NA | NA | 0.09 | NA | NA | 7.2% | 7.2% |
| 8 | 0.0068 | NA | NA | 0.03 | NA | NA | 2% | 2% |
| 9 | 0.0302 | NA | NA | 0.14 | NA | NA | 3.8% | Not stated |
| 10 | 0.0053 | NA | NA | 0.02 | NA | NA | 1.6% | 1.6% |
| 11 | 0.0988 | NA | NA | 0.45 | NA | NA | 3.1% | 3.1% |
| 12 | 0.0056 | NA | NA | 0.03 | NA | NA | 1.33% | .33% |
| 13 | 0.0831 | NA | NA | 0.38 | NA | NA | 2% | 2% |
| THD3 | NA | NA | NA | 1.79 | NA | NA | 23% | 13% |
| PWHD4 | NA | NA | NA | 2.98 | NA | NA | 23% | 22% |

3. Power Quality – Voltage fluctuations and Flicker:

For **Power Generating Modules of Registered Capacity** of less than 75 A per phase (ie 50 kW) these tests should be undertaken in accordance with Annex A.7.1.4.3. Results should be normalised to a standard source impedance, or if this results in figures above the limits set in BS EN 61000-3-11 to a suitable Maximum Impedance.

For **Power Generating Modules of Registered Capacity** of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC P28.

The standard test impedance is 0.4 Ω for a single phase **Power Generating Module** (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase **Power Generating Module** (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the **Power Factor** of the generation output is 0.98 or above):

$d \text{ max normalised value} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

The test date and location must be declared.

| | | | |
|-----------------|-----------|---------------|-----------|
| Test start date | 2022.9.20 | Test end date | 2022.9.21 |
|-----------------|-----------|---------------|-----------|

³ THD = Total Harmonic Distortion

⁴ PWHD = Partial Weighted Harmonic Distortion

| | | | | | | | | |
|--|----------|--|------|----------|--------|------|---------|--------------|
| Test location | | Test lab of GoodWe Technologies Co., Ltd (No.90 Zijin Rd., New District, Suzhou, 215011, China) | | | | | | |
| | Starting | | | Stopping | | | Running | |
| | d max | d c | d(t) | d max | d c | d(t) | P st | P lt 2 hours |
| Measured Values at test impedance | 0.398% | 0.081% | 0% | 0.113% | 0.085% | 0% | 0.044 | 0.041 |
| Normalised to standard impedance | 0.398% | 0.081% | 0% | 0.113% | 0.085% | 0% | 0.044 | 0.041 |
| Normalised to required maximum impedance | NA | NA | NA | NA | NA | NA | NA | NA |
| Limits set under BS EN 61000-3-11 | 4% | 3.3% | 3.3% | 4% | 3.3% | 3.3% | 1.0 | 0.65 |

| | | | | | | |
|--------------------|---|-----------------|----------|----|------------------|----------|
| Test Impedance | R | 0.4 | Ω | XI | 0.25 | Ω |
| Standard Impedance | R | 0.24 * 0.4 ^ | Ω | XI | 0.15 * 0.25 ^ | Ω |
| Maximum Impedance | R | NA | Ω | XI | NA | Ω |

* Applies to three phase and split single phase **Power Generating Modules**. Delete as appropriate.

^ Applies to single phase **Power Generating Module** and **Power Generating Modules** using two phases on a three phase system. Delete as appropriate.

4. Power quality – DC injection: The tests should be carried out on a single **Generating Unit**. Tests are to be carried out at three defined power levels $\pm 5\%$. At 230 V a 50 kW three phase **Inverter** has a current output of 217 A so DC limit is 543 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.

The % DC injection ("as % of rated AC current" below) is calculated as follows:

% DC injection = Recorded DC value in Amps / Base current

where the base current is the **Registered Capacity** (W) / V phase. The % DC injection should not be greater than 0.25%.

| | | | |
|---------------------------|--------|--------|--------|
| Test power level | 10% | 55% | 100% |
| Recorded DC value in Amps | 0.0204 | 0.0025 | 0.0264 |
| as % of rated AC current | 0.094% | 0.012% | 0.121% |
| Limit | 0.25% | 0.25% | 0.25% |

5. Power Factor: The tests should be carried out on a single **Power Generating Module**. Tests are to be carried out at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2.

Note that the value of voltage stated in brackets assumes a **LV** connection. This should be adjusted for **HV** as required.

| | | | |
|---------------------------|-------------------|--------------|----------------|
| Voltage | 0.94 pu (216.2 V) | 1 pu (230 V) | 1.1 pu (253 V) |
| Measured value | 0.999 | 0.998 | 0.999 |
| Power Factor Limit | >0.95 | >0.95 | >0.95 |

6. Protection – Frequency tests: These tests should be carried out in accordance with the Annex A.7.1.2.3. For trip tests, frequency and time delay should be stated. For "no trip tests", "no trip" can be stated.

| Function | Setting | | Trip test | | "No trip tests" | |
|-------------|-----------|------------|-----------|------------|-----------------|-----------------|
| | Frequency | Time delay | Frequency | Time delay | Frequency /time | Confirm no trip |
| U/F stage 1 | 47.5 Hz | 20 s | 47.48Hz | 20.05s | 47.7 Hz | no trip |

| | | | | | | |
|-------------|-------|-------|----------|-------|--------------------|---------|
| | | | | | 30 s | |
| U/F stage 2 | 47 Hz | 0.5 s | 46.98 Hz | 0.53s | 47.2 Hz 19.5 s | no trip |
| | | | | | 46.8 Hz 0.45 s | no trip |
| O/F | 52 Hz | 0.5 s | 52.02 Hz | 0.53s | 51.8 Hz 120.0 s | no trip |
| | | | | | 52.2 Hz 0.45 s | no trip |

Note. For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the protection can be used. The “No trip tests” need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

7. Protection – Voltage tests: These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Note that the value of voltage stated below assumes a **LV** connection This should be adjusted for **HV** taking account of the VT ratio as required.

| Function | Setting | | Trip test | | “No trip tests” | |
|-------------|-------------------|------------|-----------|------------|-------------------|-----------------|
| | Voltage | Time delay | Voltage | Time delay | Voltage /time | Confirm no trip |
| U/V | 0.8 pu (184 V) | 2.5 s | 183.80V | 2.54s | 188V 5.0 s | no trip |
| | | | | | 180V 2.45 s | no trip |
| O/V stage 1 | 1.14 pu (262.2 V) | 1.0 s | 263.75V | 1.02s | 258.2 V 5.0 s | no trip |
| O/V stage 2 | 1.19 pu (273.7 V) | 0.5 s | 274.80V | 0.53s | 269.7 V 0.95 s | no trip |
| | | | | | 277.7 V 0.45 s | no trip |

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

| | | | | | | |
|---|-------------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|------------------------------|
| 8.Protection – Loss of Mains test: These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4. | | | | | | |
| The following sub set of tests should be recorded in the following table. | | | | | | |
| Test Power and imbalance | 33% -5% Q Test 22 | 66% -5% Q Test 12 | 100% -5% P Test 5 | 33% +5% Q Test 31 | 66% +5% Q Test 21 | 100% +5% P Test 10 |
| Trip time. Limit is 0.5s ⁵ | 0.470s | 0.400s | 0.420s | 0.470s | 0.490s | 0.410s |
| 9.Loss of Mains Protection, Vector Shift Stability test: This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip under positive / negative vector shift. | | | | | | |
| | Start Frequen cy | Change | Confirm no trip | | | |
| Positive Vector Shift | 49.5 Hz | +50 degrees | no trip | | | |
| Negative Vector Shift | 50.5 Hz | - 50 degrees | no trip | | | |
| 10.Loss of Mains Protection, RoCoF Stability test: This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip for the duration of the ramp up and ramp down test. | | | | | | |
| Ramp range | Test frequency ramp: | | | Test Duration | | Confirm no trip |
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | | | 2.1 s | | no trip |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | | | 2.1 s | | no trip |
| 11. Limited Frequency Sensitive Mode – Over frequency test: The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. This test should be carried out in accordance with Annex A.7.1.3, which also contains the measurement tolerances. | | | | | | |
| Active Power response to rising frequency/time plots are attached if frequency injection tests are undertaken in accordance with Annex A.7.2.4. | | | | NA | | |
| Alternatively, test results should be noted below: | | | | | | |
| Test sequence at Registered Capacity >80% | Measured Active Power Output | | Frequency | | Primary Power Source | Active Power Gradient |

⁵If the device requires additional shut down time (beyond 0.5 s but less than 1 s) then this should be stated on this form.

| | | | | Droop (%) |
|--|------------------------------|-----------|----------------------|---------------------------------|
| Step a) 50.00Hz ±0.01Hz | 4994 | 50 | 5132 | / |
| Step b) 50.45Hz ±0.05Hz | 4941 | 50.45 | | 9.43% |
| Step c) 50.70Hz ±0.10Hz | 4667 | 50.7 | | 9.17% |
| Step d) 51.15Hz ±0.05Hz | 4186 | 51.15 | | 9.28% |
| Step e) 50.70Hz ±0.10Hz | 4677 | 50.7 | | 9.46% |
| Step f) 50.45Hz ±0.05Hz | 4949 | 50.45 | | 11.11% |
| Step g) 50.00Hz ±0.01Hz | 5000 | 50 | | / |
| Test sequence at Registered Capacity 40% - 60% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop (%) |
| Step a) 50.00Hz ±0.01Hz | 2515 | 50 | 2563 | / |
| Step b) 50.45Hz ±0.05Hz | 2462 | 50.45 | | 9.43% |
| Step c) 50.70Hz ±0.10Hz | 2189 | 50.7 | | 9.20% |
| Step d) 51.15Hz ±0.05Hz | 1695 | 51.15 | | 9.15% |
| Step e) 50.70Hz ±0.10Hz | 2189 | 50.70 | | 9.20% |
| Step f) 50.45Hz ±0.05Hz | 2463 | 50.45 | 2505 | 9.62% |
| Step g) 50.00Hz ±0.01Hz | 2513 | 50 | 2560 | / |

| 12. Protection – Re-connection timer | | | | | |
|--|----------------|--|--|------------------|------------------|
| Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the Power Generating Module does not reconnect at the voltage and frequency settings below; a statement of “no reconnection” can be made. | | | | | |
| Time delay setting | Measured delay | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of Table 10.1. | | | |
| 48s | 48s | At 1.16 pu (266.2 V LV connection, 127.6 V HV connection assuming 110 V ph-ph VT) | At 0.78 pu (180.0 V LV connection, 85.8 V HV connection assuming 110 V ph-ph VT) | At 47.4 Hz | At 52.1 Hz |
| Confirmation that the Power Generating Module does not re-connect. | | no re-connection | no re-connection | no re-connection | no re-connection |
| 13. Fault level contribution: These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5. Please complete each entry, even if the contribution to the fault level is zero. | | | | | |
| For Inverter output | | | | | |
| Time after fault | Volts | Amps | | | |
| 20ms | 32 | 17.3 | | | |
| 100ms | 39.2 | 24.33 | | | |
| 250ms | 35.5 | 24.25 | | | |
| 500ms | 34.3 | 24.05 | | | |
| Time to trip | 2.74 | In seconds | | | |
| 14. Self-Monitoring solid state switching: No specified test requirements. Refer to Annex A.7.1.6. | | | | | |
| It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module , the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s. | | | | | Yes |
| 15. Wiring functional tests: If required by para 15.2.1. | | | | | |
| Confirm that the relevant test schedule is attached (tests to be undertaken at time of commissioning) | | | | | NA |
| 16. Logic interface (input port) | | | | | |
| Confirm that an input port is provided and can be used to shut down the module | | | | | Yes |

| | |
|--|-----|
| Provide high level description of logic interface, e.g. details in 11.1.3.1 such as AC or DC signal (the additional comments box below can be used) | Yes |
| 17. Cyber security | |
| Confirm that the Power Generating Module has been designed to comply with cyber security requirements, as detailed in 9.1.7. | Yes |
| Additional comments. | |
| <p>The following documents are attached to this declaration:</p> <ul style="list-style-type: none"> - "Clearline Inverters DNS declaration about Logic Interface", as for required in section 14; - "Clearline Inverters DNS declaration about Cyber-security", as for required in section 15; | |

Form A2-3: Compliance Verification Report for Type A Inverter Connected Power Generating Modules

This form should be used by the **Manufacturer** to demonstrate and declare compliance with the requirements of EREC G99. The form can be used in a variety of ways as detailed below:

1. To obtain **Fully Type Tested** status (≤ 50 kW)

The **Manufacturer** can use this form to obtain **Fully Type Tested** status for a **Power Generating Module** by registering this completed form with the Energy Networks Association (ENA) Type Test Verification Report Register. Tests 1 – 15 must all be completed and compliant for the **Power Generating Module** to be classified as **Fully Type Tested**.

2. To obtain **Type Tested** status for a product

This form can be used by the **Manufacturer** to obtain **Type Tested** status for a product which is used in a **Power Generating Module** by registering this form with the relevant parts completed with the Energy Networks Association (ENA) Type Test Verification Report Register.

Where the **Manufacturer** is seeking to obtain **Type Tested** status for an **Interface Protection** device the appropriate section of Form A2-4 should be used.

3. One-off Installation

This form can be used by the **Manufacturer** or **Installer** to confirm that the **Power Generating Module** has been tested to satisfy all or part of the requirements of this EREC G99. This form shall be submitted to the **DNO** as part of the application.

A combination of (2) and (3) can be used as required, together with Form A2-4 where compliance of the **Interface Protection** is to be demonstrated on site.

Note:

Within this Form A2-3 the term **Power Park Module** will be used but its meaning can be interpreted within Form A2-3 to mean **Power Park Module**, **Generating Unit** or **Inverter** as appropriate for the context. However, note that compliance shall be demonstrated at the **Power Park Module** level.

If the **Power Generating Module** is **Fully Type Tested** and registered with the Energy Networks Association (ENA) Type Test Verification Report Register, the Installation Document (Form A3-1 or A3-2) should include the **Manufacturer's** reference number (the system reference), and this form does not need to be submitted.

Where the **Power Generating Module** is not registered with the ENA Type Test Verification Report Register or is not **Fully Type Tested** this form (all or in parts as applicable) needs to be completed and provided to the **DNO**, to confirm that the **Power Generating Module** has been tested to satisfy all or part of the requirements of this EREC G99.

| | | | |
|--|--------------------------|--|---------------------|
| PGM technology | | DNS G3Grid-Connected PV Inverter (Inverter Models: Clearline Inverter GW6000-DNS-30) | |
| Manufacturer name | | Viridian Solar Limited | |
| Address | | 68 Stirling Way, Papworth, Cambridge CB23 3GY, UK | |
| Tel | +44 (0)1480 839 865 | Tel | +44 (0)1480 839 865 |
| E-mail | info@viridiansolar.co.uk | | |
| Registered Capacity | | 6kW | |
| Energy storage capacity for Electricity Storage devices | | Not energy storage inverter | |

There are four options for Testing: (1) **Fully Type Tested** (≤ 50 kW), (2) **Type Tested** product, (3) one-off installation, (4) tested on site at time of commissioning. The check box below indicates which tests in this Form have been completed for each of the options. With the exception of **Fully Type Tested PGMs** tests may be carried out at the time of commissioning (Form A4). **Type Tested** status is suitable for devices > 50 kW where the power quality aspects need consideration on a site by site basis in accordance with EREC G5 and EREC P28.
Insert Document reference(s) for **Manufacturers' Information**

| Tested option: | 1. Fully Type Tested | 2. Type Tested product | 3. One-off Manufacturers' Info. | 4. Tested on Site at time of Commissioning |
|---|----------------------|------------------------|---------------------------------|--|
| 0. Fully Type Tested - all tests detailed below completed and evidence attached to this submission | YES | N/A | N/A | N/A |
| 1. Operating Range | N/A | | | |
| 2. PQ – Harmonics | | | | |
| 3. PQ – Voltage Fluctuation and Flicker | | | | |
| 4. PQ – DC Injection (Power Park Modules only) | | | | |
| 5. Power Factor (PF) | | | | |
| 6. Frequency protection trip and ride through tests | | | | |
| 7. Voltage protection trip and ride through tests | | | | |
| 8. Protection – Loss of Mains Test, Vector Shift and RoCoF Stability Test | | | | |
| 9. LFSM-O Test | | | | |
| 10. Protection – Reconnection Timer | | | | |
| 11. Fault Level Contribution | | | | |
| 12. Self-monitoring Solid State Switch | | | | |

There are four options for Testing: (1) **Fully Type Tested** (≤ 50 kW), (2) **Type Tested** product, (3) one-off installation, (4) tested on site at time of commissioning. The check box below indicates which tests in this Form have been completed for each of the options. With the exception of **Fully Type Tested PGMs** tests may be carried out at the time of commissioning (Form A4). **Type Tested** status is suitable for devices > 50 kW where the power quality aspects need consideration on a site by site basis in accordance with EREC G5 and EREC P28.

Insert Document reference(s) for **Manufacturers' Information**

| Tested option: | 1. Fully Type Tested | 2. Type Tested product | 3. One-off Manufacturers' Info. | 4. Tested on Site at time of Commissioning |
|---|----------------------|------------------------|---------------------------------|--|
| 13. Wiring functional tests if required by para 15.2.1 (attach relevant schedule of tests) | | | | |
| 14. Logic Interface (input port) | | | | |
| 15. Cyber security | | | | |

Manufacturer compliance declaration. - I certify that all products supplied by the company with the above **Type Tested Manufacturer's** reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site **Modifications** are required to ensure that the product meets all the requirements of EREC G99.

| | | | |
|--------|--|--------------|--|
| Signed |  KT Tan 6 th July 2023 | On behalf of |  Viridian Solar Limited |
|--------|--|--------------|--|

Note that testing can be done by the **Manufacturer** of an individual component or by an external test house.

Where parts of the testing are carried out by persons or organisations other than the **Manufacturer** then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.

A2-3 Compliance Verification Report –Tests for Type A Inverter Connected Power Generating Modules – test record

1. Operating Range: Tests should be carried with the **Power Generating Module** operating at **Registered Capacity** and connected to a suitable test supply or grid simulation set. The power supplied by the primary source shall be kept stable within $\pm 5\%$ of the apparent power value set for the entire duration of each test sequence.

Frequency, voltage and **Active Power** measurements at the output terminals of the **Power Generating Module** shall be recorded every second. The tests will verify that the **Power Generating Module** can operate within the required ranges for the specified period of time.

The **Interface Protection** shall be disabled during the tests.

In case of a PV **Power Park Module** the PV primary source may be replaced by a DC source.

In case of a full converter **Power Park Module** (eg wind) the primary source and the prime mover **Inverter**/rectifier may be replaced by a DC source.


Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.

Note that the value of voltage stated in brackets assumes a **LV** connection. This should be adjusted for **HV** as required.

Test 1

Voltage = 85% of nominal (195.5 V),
Frequency = 47 Hz,
Power Factor = 1,
Period of test 20 s


Test results : Pass







Test 2

Voltage = 85% of nominal (195.5 V),
Frequency = 47.5 Hz,
Power Factor = 1,
Period of test 90 minutes

Test results : Pass



| | |
|--|---|
| <p>Test 3</p> <p>Voltage = 110% of nominal (253 V), Frequency = 51.5 Hz, Power Factor = 1, Period of test 90 minutes</p> | <p>Test results : Pass</p>  |
| <p>Test 4</p> <p>Voltage = 110% of nominal (253 V), Frequency = 52.0 Hz, Power Factor = 1, Period of test 15 minutes</p> | <p>Test results : Pass</p>  |
| <p>Test 5</p> <p>Voltage = 100% of nominal (230 V), Frequency = 50.0 Hz, Power Factor = 1, Period of test = 90 minutes</p> | <p>Test results : Pass</p>  |
| <p>Test 6 RoCoF withstand</p> <p>Confirm that the Power Generating Module is capable of staying connected to the Distribution Network and operate at rates of change of frequency up to 1 Hzs⁻¹ as measured over a period of 500 ms. Note that this is not expected to be demonstrated on site.</p> | <p>Test results : Pass</p>  |

2. Power Quality – Harmonics:

For **Power Generating Modules** of **Registered Capacity** of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12, and measurements for the 2nd – 13th harmonics should be provided. The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 61000-3-12 for three phase equipment. For three phase **Power Generating Modules**, measurements for all phases should be provided.

For **Power Generating Modules** of **Registered Capacity** of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC G5.

The rating of the **Power Generating Module** (per phase) should be provided below, and the Total Harmonic Distortion (THD) and Partial Weighted Harmonic Distortion (PWhD) should be provided at the bottom of this section.

Power Generating Module tested to BS EN 61000-3-12

| | | | | | | | | |
|---|---|----|----|--------------------------|----|-----|---|------------|
| Power Generating Module rating per phase (rpp) | | | | 6 | | kVA | Harmonic % = Measured Value (A) x 23/rating per phase (kVA) | |
| Single or three phase measurements (for single phase measurements, only complete L1 columns below). | | | | Single phase | | | | |
| Harmonic | At 45-55% of Registered Capacity | | | | | | Limit in BS EN 61000-3-12 | |
| | Measured Value (MV) in Amps | | | Measured Value (MV) in % | | | | |
| | L1 | L2 | L3 | L1 | L2 | L3 | 1 phase | 3 phase |
| 2 | 0.0248 | NA | NA | 0.09 | NA | NA | 8% | 8% |
| 3 | 0.0113 | NA | NA | 0.04 | NA | NA | 21.6% | Not stated |
| 4 | 0.0123 | NA | NA | 0.05 | NA | NA | 4% | 4% |
| 5 | 0.0082 | NA | NA | 0.03 | NA | NA | 10.7% | 10.7% |
| 6 | 0.0229 | NA | NA | 0.09 | NA | NA | 2.67% | 2.67% |
| 7 | 0.0121 | NA | NA | 0.05 | NA | NA | 7.2% | 7.2% |
| 8 | 0.0319 | NA | NA | 0.12 | NA | NA | 2% | 2% |
| 9 | 0.0072 | NA | NA | 0.03 | NA | NA | 3.8% | Not stated |
| 10 | 0.1049 | NA | NA | 0.40 | NA | NA | 1.6% | 1.6% |
| 11 | 0.0062 | NA | NA | 0.02 | NA | NA | 3.1% | 3.1% |
| 12 | 0.0897 | NA | NA | 0.34 | NA | NA | 1.33% | 1.33% |
| 13 | 0.0059 | NA | NA | 0.02 | NA | NA | 2% | 2% |

| | | | | | | | | |
|-------------------|---------------------------------------|----|----|--------------------------|----|----|---------------------------|------------|
| THD ¹ | NA | NA | NA | 1.57 | NA | NA | 23% | 13% |
| PWHD ² | NA | NA | NA | 2.19 | NA | NA | 23% | 22% |
| Harmonic | At 100% of Registered Capacity | | | | | | Limit in BS EN 61000-3-12 | |
| | Measured value (MV) in Amps | | | Measured value (MV) in % | | | | |
| | L1 | L2 | L3 | L1 | L2 | L3 | 1 phase | 3 phase |
| 2 | 0.0443 | NA | NA | 0.17 | NA | NA | 8% | 8% |
| 3 | 0.0367 | NA | NA | 0.14 | NA | NA | 21.6% | Not stated |
| 4 | 0.0171 | NA | NA | 0.07 | NA | NA | 4% | 4% |
| 5 | 0.0140 | NA | NA | 0.05 | NA | NA | 10.7% | 10.7% |
| 6 | 0.0103 | NA | NA | 0.04 | NA | NA | 2.67% | 2.67% |
| 7 | 0.0304 | NA | NA | 0.12 | NA | NA | 7.2% | 7.2% |
| 8 | 0.0101 | NA | NA | 0.04 | NA | NA | 2% | 2% |
| 9 | 0.0379 | NA | NA | 0.15 | NA | NA | 3.8% | Not stated |
| 10 | 0.0100 | NA | NA | 0.04 | NA | NA | 1.6% | 1.6% |
| 11 | 0.1306 | NA | NA | 0.50 | NA | NA | 3.1% | 3.1% |
| 12 | 0.0076 | NA | NA | 0.03 | NA | NA | 1.33% | .33% |
| 13 | 0.1198 | NA | NA | 0.46 | NA | NA | 2% | 2% |
| THD ³ | NA | NA | NA | 1.15 | NA | NA | 23% | 13% |
| PWHD ⁴ | NA | NA | NA | 2.98 | NA | NA | 23% | 22% |

¹ THD = Total Harmonic Distortion

² PWHD = Partial Weighted Harmonic Distortion

³ THD = Total Harmonic Distortion

⁴ PWHD = Partial Weighted Harmonic Distortion

3. Power Quality – Voltage fluctuations and Flicker:

For **Power Generating Modules** of **Registered Capacity** of less than 75 A per phase (ie 50 kW) these tests should be undertaken in accordance with Annex A.7.1.4.3. Results should be normalised to a standard source impedance, or if this results in figures above the limits set in BS EN 61000-3-11 to a suitable Maximum Impedance.

For **Power Generating Modules** of **Registered Capacity** of greater than 75 A per phase (ie 50 kW) the installation shall be designed in accordance with EREC P28.

The standard test impedance is 0.4 Ω for a single phase **Power Generating Module** (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase **Power Generating Module** (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the **Power Factor** of the generation output is 0.98 or above):

$d_{\text{max normalised value}} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

The test date and location must be declared.

| | | | | | | | | |
|--|----------|--|------|---------------|--------|------|-----------|--------------|
| Test start date | | 2022.9.20 | | Test end date | | | 2022.9.21 | |
| Test location | | Test lab of GoodWe Technologies Co., Ltd (No.90 Zijin Rd., New District, Suzhou, 215011, China) | | | | | | |
| | Starting | | | Stopping | | | Running | |
| | d max | d c | d(t) | d max | d c | d(t) | P st | P It 2 hours |
| Measured Values at test impedance | 1.110% | 1.071% | 0% | 1.421% | 0.081% | 0% | 0.208 | 0.163 |
| Normalised to standard impedance | 1.110% | 1.071% | 0% | 1.421% | 0.081% | 0% | 0.208 | 0.163 |
| Normalised to required maximum impedance | NA | NA | NA | NA | NA | NA | NA | NA |
| Limits set under BS EN 61000-3-11 | 4% | 3.3% | 3.3% | 4% | 3.3% | 3.3% | 1.0 | 0.65 |

| | | | | | | |
|--------------------|---|-----------------|----------|----|------------------|----------|
| Test Impedance | R | 0.4 | Ω | XI | 0.25 | Ω |
| Standard Impedance | R | 0.24 * 0.4 ^ | Ω | XI | 0.15 * 0.25 ^ | Ω |
| Maximum Impedance | R | NA | Ω | XI | NA | Ω |

* Applies to three phase and split single phase **Power Generating Modules**. Delete as appropriate.

^ Applies to single phase **Power Generating Module** and **Power Generating Modules** using two phases on a three phase system. Delete as appropriate.

4. Power quality – DC injection: The tests should be carried out on a single **Generating Unit**. Tests are to be carried out at three defined power levels $\pm 5\%$. At 230 V a 50 kW three phase **Inverter** has a current output of 217 A so DC limit is 543 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.

The % DC injection ("as % of rated AC current" below) is calculated as follows:

% DC injection = Recorded DC value in Amps / Base current

where the base current is the **Registered Capacity** (W) / V phase. The % DC injection should not be greater than 0.25%.

| | | | |
|---------------------------|--------|--------|--------|
| Test power level | 10% | 55% | 100% |
| Recorded DC value in Amps | 0.0190 | 0.0493 | 0.0423 |
| as % of rated AC current | 0.073% | 0.189% | 0.162% |
| Limit | 0.25% | 0.25% | 0.25% |

5. Power Factor: The tests should be carried out on a single **Power Generating Module**. Tests are to be carried out at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2.

Note that the value of voltage stated in brackets assumes a **LV** connection. This should be adjusted for **HV** as required.

| | | | |
|---------------------------|-------------------|--------------|----------------|
| Voltage | 0.94 pu (216.2 V) | 1 pu (230 V) | 1.1 pu (253 V) |
| Measured value | 0.999 | 0.999 | 0.999 |
| Power Factor Limit | >0.95 | >0.95 | >0.95 |

6. Protection – Frequency tests: These tests should be carried out in accordance with the Annex A.7.1.2.3. For trip tests, frequency and time delay should be stated. For "no trip tests", "no trip" can be stated.

| Function | Setting | | Trip test | | "No trip tests" | |
|-------------|-----------|------------|-----------|------------|-----------------|-----------------|
| | Frequency | Time delay | Frequency | Time delay | Frequency /time | Confirm no trip |
| U/F stage 1 | 47.5 Hz | 20 s | 47.48 Hz | 20.06s | 47.7 Hz | no trip |

| | | | | | | |
|-------------|-------|-------|----------|-------|--------------------|---------|
| | | | | | 30 s | |
| U/F stage 2 | 47 Hz | 0.5 s | 46.98 Hz | 0.55s | 47.2 Hz 19.5 s | no trip |
| | | | | | 46.8 Hz 0.45 s | no trip |
| O/F | 52 Hz | 0.5 s | 52.02 Hz | 0.55s | 51.8 Hz 120.0 s | no trip |
| | | | | | 52.2 Hz 0.45 s | no trip |

Note. For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the protection can be used. The “No trip tests” need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

7. Protection – Voltage tests: These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Note that the value of voltage stated below assumes a **LV** connection This should be adjusted for **HV** taking account of the VT ratio as required.

| Function | Setting | | Trip test | | “No trip tests” | |
|-------------|----------------------|------------|-----------|------------|-------------------|-----------------|
| | Voltage | Time delay | Voltage | Time delay | Voltage /time | Confirm no trip |
| U/V | 0.8 pu (184 V) | 2.5 s | 183.41V | 2.54s | 188V 5.0 s | no trip |
| | | | | | 180V 2.45 s | no trip |
| O/V stage 1 | 1.14 pu (262.2 V) | 1.0 s | 263.31V | 1.03s | 258.2 V 5.0 s | no trip |
| O/V stage 2 | 1.19 pu (273.7 V) | 0.5 s | 274.84V | 0.54s | 269.7 V 0.95 s | no trip |
| | | | | | 277.7 V 0.45 s | no trip |

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

| | | | | | | |
|---|-------------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|---------------------------------|
| 8. Protection – Loss of Mains test: These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4. | | | | | | |
| The following sub set of tests should be recorded in the following table. | | | | | | |
| Test Power and imbalance | 33% -5% Q Test 22 | 66% -5% Q Test 12 | 100% -5% P Test 5 | 33% +5% Q Test 31 | 66% +5% Q Test 21 | 100% +5% P Test 10 |
| Trip time. Limit is 0.5s ⁵ | 0.470s | 0.400s | 0.420s | 0.470s | 0.490s | 0.410s |
| 9. Loss of Mains Protection, Vector Shift Stability test: This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip under positive / negative vector shift. | | | | | | |
| | Start Frequen cy | Change | Confirm no trip | | | |
| Positive Vector Shift | 49.5 Hz | +50 degrees | no trip | | | |
| Negative Vector Shift | 50.5 Hz | - 50 degrees | no trip | | | |
| 10. Loss of Mains Protection, RoCoF Stability test: This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip for the duration of the ramp up and ramp down test. | | | | | | |
| Ramp range | Test frequency ramp: | | | Test Duration | | Confirm no trip |
| 49.0 Hz to 51.0 Hz | +0.95 Hzs ⁻¹ | | | 2.1 s | | no trip |
| 51.0 Hz to 49.0 Hz | -0.95 Hzs ⁻¹ | | | 2.1 s | | no trip |
| 11. Limited Frequency Sensitive Mode – Over frequency test: The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. This test should be carried out in accordance with Annex A.7.1.3, which also contains the measurement tolerances. | | | | | | |
| Active Power response to rising frequency/time plots are attached if frequency injection tests are undertaken in accordance with Annex A.7.2.4. | | | | | NA | |
| Alternatively, test results should be noted below: | | | | | | |
| Test sequence at Registered Capacity >80% | Measured Active Power Output | | Frequency | Primary Power Source | | Active Power Gradient |

⁵If the device requires additional shut down time (beyond 0.5 s but less than 1 s) then this should be stated on this form.

| | | | | Droop (%) |
|--|------------------------------|-----------|----------------------|---------------------------------|
| Step a) 50.00Hz ±0.01Hz | 6005 | 50 | 6177 | / |
| Step b) 50.45Hz ±0.05Hz | 5944 | 50.45 | | 9.84% |
| Step c) 50.70Hz ±0.10Hz | 5617 | 50.7 | | 9.28% |
| Step d) 51.15Hz ±0.05Hz | 5031 | 51.15 | | 9.24% |
| Step e) 50.70Hz ±0.10Hz | 5618 | 50.7 | | 9.30% |
| Step f) 50.45Hz ±0.05Hz | 5944 | 50.45 | | 9.84% |
| Step g) 50.00Hz ±0.01Hz | 5999 | 50 | | / |
| Test sequence at Registered Capacity 40% - 60% | Measured Active Power Output | Frequency | Primary Power Source | Active Power Gradient Droop (%) |
| Step a) 50.00Hz ±0.01Hz | 3002 | 50 | 3055 | / |
| Step b) 50.45Hz ±0.05Hz | 2943 | 50.45 | | 10.17% |
| Step c) 50.70Hz ±0.10Hz | 2615 | 50.7 | | 9.30% |
| Step d) 51.15Hz ±0.05Hz | 2025 | 51.15 | | 9.21% |
| Step e) 50.70Hz ±0.10Hz | 2616 | 50.7 | | 9.33% |
| Step f) 50.45Hz ±0.05Hz | 2944 | 50.45 | | 10.34% |
| Step g) 50.00Hz ±0.01Hz | 3000 | 50 | | / |

| 12. Protection – Re-connection timer | | | | | |
|--|----------------|--|--|------------------|------------------|
| Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the Power Generating Module does not reconnect at the voltage and frequency settings below; a statement of “no reconnection” can be made. | | | | | |
| Time delay setting | Measured delay | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of Table 10.1. | | | |
| 48s | 48s | At 1.16 pu (266.2 V LV connection, 127.6 V HV connection assuming 110 V ph-ph VT) | At 0.78 pu (180.0 V LV connection, 85.8 V HV connection assuming 110 V ph-ph VT) | At 47.4 Hz | At 52.1 Hz |
| Confirmation that the Power Generating Module does not re-connect. | | no re-connection | no re-connection | no re-connection | no re-connection |
| 13. Fault level contribution: These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5. Please complete each entry, even if the contribution to the fault level is zero. | | | | | |
| For Inverter output | | | | | |
| Time after fault | Volts | Amps | | | |
| 20ms | 88 | 17.2 | | | |
| 100ms | 49.2 | 26.58 | | | |
| 250ms | 39.5 | 26.81 | | | |
| 500ms | 35.7 | 25.94 | | | |
| Time to trip | 2.76 | In seconds | | | |
| 14. Self-Monitoring solid state switching: No specified test requirements. Refer to Annex A.7.1.6. | | | | | |
| It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module , the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s. | | | | | Yes |
| 15. Wiring functional tests: If required by para 15.2.1. | | | | | |
| Confirm that the relevant test schedule is attached (tests to be undertaken at time of commissioning) | | | | | NA |
| 16. Logic interface (input port) | | | | | |
| Confirm that an input port is provided and can be used to shut down the module | | | | | Yes |

| | |
|--|-----|
| Provide high level description of logic interface, e.g. details in 11.1.3.1 such as AC or DC signal (the additional comments box below can be used) | Yes |
| 17. Cyber security | |
| Confirm that the Power Generating Module has been designed to comply with cyber security requirements, as detailed in 9.1.7. | Yes |
| Additional comments. | |
| <p>The following documents are attached to this declaration:</p> <ul style="list-style-type: none"> - "Clearline Inverters DNS declaration about Logic Interface", as for required in section 14; - "Clearline Inverters DNS declaration about Cyber-security", as for required in section 15; | |